

—	Vapour Check / Vapour Barrier (Visqueen or Equal Approved) - All joints to be lapped by min 150mm and taped to prevent screed migration.
—	Single Sided jointing tape (Visqueen or equal approved).
—	Double Sided jointing tape (Visqueen or equal approved)
---	Visqueen Zedex High Performance CPT DPC
---	Visqueen Random R400 Membrane to be installed above beam and block floor, all joints are to be minimised and taped and lapped (min 150mm) in accordance with manufacturers recommendations and standard details.

CONSTRUCTION

condy lofthouse
architects

Title		
Proposed GA Section A-A - Plot 1		
Scale	Date	Drawing No
1:25@A1	05/14/26	
Drawing No	Revision	
26-023-150		



00 0.5 01 02

SCALE BAR 1:25 (in metres)