

	Vapour Check/Vapour Barrier (Visqueen or Equivalant approved) - All joints to be lapped by min 150mm and taped to prevent screed migration.
	Single Sided jointing tape (Visqueen or equal approved)
	Double Sided jointing tape (Visqueen or equal approved)
	Visqueen Zedex High Performance CPT DPC
	Visqueen Randon R400 Membrane to be installed above beam and block floor, all joints are to be minimised and taped and lapped (min 150mm) in accordance with manufacturers recommendations and standard details.

NOTE: To be read in conjunction with S.E. Drawings provided by SWF CONSULTANTS LTD issued 16/12/20
Detail subject to S.E. comment / approval

NOTE: To be read in conjunction with SAP Assess
Report provided by Bridgewater Energy issued
31/03/20

B Minor Amendments To Partitions To JL Jul '26

A Amended To Suit Eaves Detail	JL Jun '26
* First Issue	II May '2

CONSTRUCTION

CONSTRUCTION

condy lofthouse

architects

106 | *Journal of Management Inquiry* 26(1)

Built Group Ltd

Project

Lyme Grove, Longview, Huyton

Title _____

Proposed GA Section A-A - House Plots 2-5

Scale	Date	Drawn
-------	------	-------


1:25@A1 May '26

Drawing No. 26-023-152

Unit 17 Connect Business 0151 207
Village 4371
24 Derby Road info@condylorhouse.co

Liverpool L5 9PR www.con2yloffhouse.co.uk

PLOT:
2 & 3 / 4 & 5



Section B-B