

Calculation Summary								
Label	CalcType	Units	Ang	Max	Min	Uniformity (Min/Avg)	Diversity (Min/Max)	Meter Type
Building Perimeter	Illuminance	Lux	12.15	28	3	0.25	0.11	Horizontal
Car Park	Illuminance	Lux	20.02	104	7	0.35	0.07	Horizontal
Loading Bay	Illuminance	Lux	152.93	240	63	0.41	0.26	Horizontal
Service Yard	Illuminance	Lux	50.17	186	20	0.40	0.11	Horizontal

