

EXTERNAL WINDOW AND DOOR SCHEDULE - PRESCOT POLICE STATION								
	WINDOW REF	LOCATION	TYPE	STRUCTURAL - OPENING Subject to site measurement	GLAZING	DETAILS / ADDITIONAL REQUIREMENTS	FIRE STRATEGY Ironmongery	
GROUND FLOOR	APT. 1	GW 01	Kitchen / Dining	A	1060 x 1950	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		DE01	Hall	1	940 x 2850	Clear	Existing Door with Tudor Arch Glazed Fanlight - Repair and repaint where required	
		GW 02	Lounge	A	690 x 2040	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 03	Lounge	A	1090 x 2040	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 04	Lounge	A	1090 x 2040	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 05	Lounge	A	690 x 2040	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 20	Bedroom 2	C	1490 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD05	
		GW 21	Bedroom 1	B	1235 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		GW 22	Ensuite	J	610 x 1305	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD04	
	GW 23	Ensuite	J	610 x 1305	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD04		
	APT. 2	GW 06	Lounge	A	1050 x 1950	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 07	Kitchen / Dining	A	1080 x 1950	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD02	
		GW 08	Bathroom	B	1075 x 2020	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		GW 09	Bedroom 2	C	1370 x 2030	Clear	New Timber Sliding Sash Window - Refer to detail AD05 - to replace modern glass block window	
		GW 10	Bedroom 1	D	770 x 485	Clear	New Replacement Timber Casement Window - Fixed opening light	
		AGW.02	Bedroom 1	B	935 x 1970	Clear	New Timber Sliding Sash Window - Refer to detail AD01 - Infill into existing opening	
	APT. 3	GW 11	Bedroom 1	B	1020 x 2040	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		GW 12	Bedroom 2	B	1020 x 2015	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		GW 13	Bedroom 2	B	1020 x 2015	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		GW 14	Hall	E	980 x 1240	Special	Original Cell Window to remain - Repair opening mechanism and repaint	
		AGW.01	Lounge	F	1370 x 2910	Clear	New top fanlight and double door opening set - Form new opening - Glazed Juliette to be inc.	
		GW 15	Lounge	G	750 x 480	Special	Original Cell Window to remain - Repair opening mechanism and repaint	
		GW 16	Hall	G	750 x 480	Special	Original Cell Window to remain - Repair opening mechanism and repaint	
		GW 17	Hall	G	750 x 480	Special	Original Cell Window to remain - Repair opening mechanism and repaint	
		GW 18	Bathroom	H	1625 x 620	Opaque	New Replacement Timber Casement Window - Two openers required	
	Communals	DE02	Ramped Entrance	2	1560 x 3420	Clear	Existing Door with Detailed Arch Glazed Fanlight - Repair and repaint where necessary	
		DE03	First Floor Access Entrance	3	1300 x 2710	N/A	Existing Arched Door - Repair and repaint - Repair and repaint where necessary	
		DE05	Courtyard Entrance	4	1065 x 2200	N/A	Existing Door - Repair and repaint where necessary	
		DE06	Courtyard Stepped Entrance	5	1065 x 2100	N/A	Existing Arched Door - Repair and repaint where necessary	
		DE07	Plant Room	6	1080 x 1825	N/A	Existing Door - Repair and repaint where necessary	
GW 19		Communal Hall	J	1175 x 850	Clear	New Replacement Timber Casement Window - Two openers required		
GW 24		Plant Room	K	1175 x 850	Clear	New Replacement Timber Casement Window - Two openers required		
GW 25		Plant Room	L	1625 x 620	Clear	New Replacement Timber Casement Window - Two openers required		
FIRST FLOOR	APT. 4	FW 01	Kitchen / Dining	M	1060 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD03	
		FW 02	Lounge	M	1060 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD03	
		FW 03	Lounge	M	1060 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD03	
		FW 20	Bedroom 2	R	1380 x 1965	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD05	
		FW 21	Bedroom 1	S	1235 x 1685	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		FW 22	Ensuite	T	440 x 815	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD04	
		FW 23	Ensuite	S	890 x 1305	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
	APT. 5	FW 04	Kitchen / Dining	N	935 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD06	
		FW 05	Lounge	M	1055 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD03	
		FW 06	Bedroom 1	M	1105 x 1975	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD03	
	APT.6 (Duplex)	FW 10	Bedroom 2	P	1235 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		FW 11	Bedroom 1	P	1235 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		RW01	Lounge / Kitchen / Dining	U	780 x 1400	Clear	New heritage rooflight to be fitted between existing roof structure	
		RW02	Lounge / Kitchen / Dining	V	940 x 1400	Clear	New heritage rooflight to be fitted between existing roof structure	
	APT.7 (Duplex)	FW 12	Bedroom 2	P	1225 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		FW 13	Ensuite	Q	925 x 2420	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD04	
		FW 14	Ensuite	Q	610 x 2025	Opaque	New Replacement Timber Sliding Sash Window - Refer to detail AD04	
		FW 15	Bedroom 1	P	1025 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
		FW 16	Snug / Study	P	1025 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	
AFW.01		Snug / Study	Q	940 x 2415	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD04		
FW 17		Hallway / Stairs	P	1230 x 2415	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01		
RW03		Lounge / Kitchen / Dining	W	1340 x 1400	Clear	New heritage rooflight to be fitted between existing roof structure		
COMMUNAL	FW 07	Stairwell 4	O	455 x 2705	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD07	OV	
	FW 08	Stairwell 4	O	455 x 2705	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD07	OV	
	FW 09	First Floor Lobby	P	1210 x 2460	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01	OV	
	FW 18	First Floor Communal Corridor	P	1230 x 2415	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01		
	FW 19	First Floor Communal Corridor	P	1230 x 2415	Clear	New Replacement Timber Sliding Sash Window - Refer to detail AD01		

NOTE :

NEW REPLACEMENT TIMBER SLIDING SASH WINDOWS

Replacements - Retain the original depth of 'reveal', this is essential if the character of the building is not to be destroyed. Ensure glazing bars / beads are of the appropriate thickness and profile (including all lambs tongue details beads internal and external). Window manufacturer to replicate detailing. New windows should be sympathetic in scale, design and detail to the originals. Where applicable, safety Glazing to BS6206 : 1981 must be installed in all critical locations, i.e. between finished floor level and 800mm above that level in all walls and partitions and between finished floor level and 1500mm above that level in all doors and door side panels within 300mm of either edge of door.

Painting - Where draught-proofing measures have been carried out, special care is needed when painting the windows. Brush type draught-strips in particular will be ruined once clogged with paint, and although paints will not stick easily to rubber, some solvent paint removers attack plastic. If new windows are produced, they should be ordered primed only and painted on site (again care should be taken to protect the draught strips).

Where inner glazing in situ - All inner glazing profiles to be carefully removed - there will be no requirement for inner glazing with new replacement windows

NEW TIMBER WINDOWS CASEMENTS

All new timber doors and windows shall be double glazed and glazed from the inside of the building with the manufacturer's seals and beads on all glazing blocks to allow drainage and shall conform to requirements of BS6262. The Contractor is to include for the use of clear float glass.

The U-value of the new windows is to give a thermal resistance equal or better than the current requirements in British Standards and Building Regulations Approved Document L1.

All glazing is to comply with Approved Document K4 Section 5. Safety glazing to Class 3 of BS EN 12600 or Class C of BS6206 and must be installed in critical locations, ie. between finished floor level and 800mm above that level in all walls and partitions and between finished floor level and 1500mm above that level in all doors and door side panels within 300mm of either edge of door.

The inner panes to be Low E coated and have a minimum void between panes of 16mm and to be clearly marked in accordance with BS5713. All glazing gaskets and weather seals shall be non-migratory EPDM material to BS 4255: Part 1: 1986.

All window installations to be provided with 10-year guarantee, in accordance with the Glass and Glazing Federation's recommendations.



Revision	Date	Description	Drawn
Rev A	13.08.2024	Amended schedule in line with LPA's latest comments to reflect floor plans and elevations and window details, annotation updated.	JT

This drawing is covered by copyright which remains with KWL Architects Ltd. and must not be reproduced in any form without their express permission. This drawing should not be scaled for construction purposes, use figured dimensions only.

Client PRIMA			
Project FORMER SITE OF POLICE STATION, DERBY STREET, PRESCOT			
Drawing FORMER POLICE STATION: PROPOSED WINDOW DOOR SCHEDULE SHEET 2 OF 2			
Scale NTS @ A3	Date 13.06.2024	Drawn JT	Checked RJS
Job No. 5388	Dwg No. SCH02	Revision A	Status PLANNING



KWL Architects

Poplar House Hazell Drive
Newport S.Wales NP108FY
T.+44 (0)1633 81 71 71
www.kwlarchitects.co.uk