



Knowsley Council

**REGENERATION AND ECONOMIC DEVELOPMENT
DEPARTMENT**

TOWN AND COUNTRY PLANNING ACT 1990

PLANNING PERMISSION

Application No: 24/00554/FUL

Name and address of applicant

Whitakers Garden Centre
James Whitaker & Sons (Nurserymen)
Ltd
Liverpool Road
Prescot
Merseyside
L34 5UD

Name and address of agent

Life Architecture Ltd
4 Grafton Walk
West Kirby
Wirral
CH48 7EJ

Date of Receipt: 14 October 2024

Date Valid: 10 December 2024

Address/Location Of Development:

Pilkington Court
Sinclair Way
Prescot Business Park
Prescot
Knowsley
L34 1QG

Description of Development:

**ERECTION OF A STORAGE/WAREHOUSE BUILDING (USE CLASS B8) AND
ASSOCIATED CAR PARKING**

The Council of the Metropolitan Borough of Knowsley hereby give notice in pursuance of the above Act(s) that Planning Permission has been **granted** for the carrying out of the development referred to above in accordance with the application and plans submitted subject to the following condition(s):

1. The development must be begun not later than the expiration of three years beginning with the date of this permission.

Reason: In order to comply with the requirements of Section 91 of the Town and Country Planning Act 1990 (as amended).

2. The development hereby permitted shall be carried out in accordance with the approved plans and documents listed in Schedule 1.

Reason: For the avoidance of doubt.

3. Notwithstanding any description of materials in the application, no above ground construction works shall take place until full specification of materials to be used externally on the building has been submitted to and approved in writing by the Local Planning Authority. Such details shall include the type, colour and texture of the materials and should be reflective of those within the surrounding area, unless otherwise agreed in writing by the Local Planning Authority. The development shall be carried out only in accordance with the agreed schedule of materials.

Reason: To preserve the character and appearance of the local area and in the interests of visual amenity and to comply with Policy CS19 of the Knowsley Local Plan Core Strategy, adopted January 2016, and the National Planning Policy Framework.

4. Prior to the commencement of development, details of a sustainable surface water drainage scheme and a foul water drainage scheme shall be submitted to and approved in writing by the Local Planning Authority. The drainage schemes must include:
 - (i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include evidence of an assessment of ground conditions and the potential for infiltration of surface water in accordance with BRE365 (the LLFA will be expecting above ground and green SuDS as a source control to be prioritised to promote water quality, amenity and biodiversity);
 - (ii) Drainage drawings, summary calculations and results of all investigations detailing the surface water drainage works as appropriate;
 - (iii) Should the surface water from the proposal is to connect to the public sewer system, provision of evidence that the site has an agreed discharge point and rate for post-development situation from responsible authorities will be required.
 - (iv) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations);
 - (v) Should the proposals include works to an ordinary watercourse, under the Land drainage Act 1991, as amended by the Flood and Water Management Act 2010, a prior consent of the Lead Local Flood Authority will be required for this work. This consent will be required as a separate permission to planning.
 - (vi) Model Information (Micro Drainage or similar approved) to include a plan showing pipework model numbering and network details.
 - (vii) Results showing all the modelling criteria and summary network results for critical 1 in 2 year, 1 in 30 year and 1 in 100 year plus 40% CC storm events showing maximum water level, flow and velocity and details of any surface flooding anticipated will be required.
 - (viii) A drawing showing the proposed impermeable and permeable areas, suitably annotated will be required.
 - (ix) Drainage Plan, including levels of the proposed drainage systems including proposed ground and finished floor levels in AOD, showing drainage layout, manholes including cover and invert levels, pipe sizes and gradients, all on -line controls, on and off line storage structures and outfall details will be required.
 - (x) Plan showing overland exceedance routes in the event of a failure of the drainage system or storm event in excess of the 1 in 100 + 40% CC storm event will be required.
 - (xi) Summarised drainage report setting out the proposed drainage strategy, design criteria, and results of the calculations/modelling demonstrating compliance with the above will be required.

- (xii) Where third party agreements to construct sewers and to discharge flows are required, then written evidence of these two agreements shall be provided.
- (xiii) A timetable for implementation of the drainage works including an assessment of any phasing of the development shall be expected.
- (xiv) Demonstration of adequate water quality of the off-site surface water flows (draining into a sewer, watercourse and ground) in accordance with the Simplified Index Approach as set out within Section 26 of the SUDS Manual (C753) can be achieved during all phases of the development will be required.
- (xv) In designing the drainage strategy, it must demonstrate the surface water runoff up to 1 in 100 year plus 40% CC event will be retained within the site with no negative impact on surrounding areas. At the same time, an assessment will be required to demonstrate that the site will not be impacted by off site surface water runoff in post development situation.
- (xvi) Where SuDS are only proposed in part or not at all, then a full justification statement shall be provided to demonstrate why it is not considered appropriate or reasonable.
- (xvii) Incorporate mitigation measures to manage the risk of sewer surcharge where applicable; and
- (xviii) Foul and surface water shall drain on separate systems.

The approved schemes shall also be in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards.

Prior to occupation of the proposed development, the drainage schemes shall be completed in accordance with the approved details and retained thereafter for the lifetime of the development.

Reason: To ensure a satisfactory drainage system is provided to serve the site in accordance with Paragraph 163 of the National Planning Policy Framework, House of Commons Written Statement 161 for Sustainable Drainage Systems, Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) and Policies CS2 and CS24 of the Knowsley Local Plan: Core Strategy (January 2016).

5. Prior to occupation of the development a sustainable drainage management and maintenance plan for the lifetime of the development shall be submitted to the local planning authority and agreed in writing. The sustainable drainage management and maintenance plan shall include as a minimum:
 - (i) Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a resident's management company;
 - (ii) Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime;
 - (iii) Details for planned maintenance and a mechanism for remedial and urgent repair works and
 - (iv) Means of access for inspection and maintenance purposes.
 The development shall subsequently be completed, maintained and managed in accordance with the approved plan.

Reason: To ensure that management arrangements are in place for the sustainable drainage system in order to manage the risk of flooding and pollution during the lifetime of the development

6. No above ground works shall take place until a plan showing details of the areas for cycle parking, motorcycle parking and electric vehicle charging has been submitted

to and approved in writing by the local planning authority, and the development shall not be brought into use until such areas have been provided, constructed and surfaced in complete accordance with the approved plans. These areas shall be retained at all times thereafter.

Reason: To ensure that adequate on site vehicle parking/manoeuvring facilities are provided in the interests of highway safety and amenity, and to comply with Policies CS2, CS7 and CS19 of the Knowsley Local Plan Core Strategy, adopted January 2016.

7. Development shall not commence until a scheme has been submitted to and approved in writing by the local planning authority which specifies the provisions to be made for the control of noise emanating from the site. The scheme shall be based on the results of a noise assessment which suitably characterises the noise climate at nearby residential dwellings (Tenlands Drive) both prior to and following the operation of the development permitted.

The following noise levels shall be met after implementation of the scheme; Fixed plant and machinery associated with the development shall be designed to a level that is at least 5dB(A) below the existing LA90 background noise level as measured during the relevant time period. Any tonal, impulsive and/or irregular noise would be addressed by imposing a penalty as per the methodology set out in BS 4142:2014+A1:2019, Methods for rating and assessing industrial and commercial sound. Noise limits for fixed plant are to apply at a position 1 metre from the closest affected window of the nearest noise sensitive property.

All works which form part of the scheme shall be implemented in full in accordance with the scheme as agreed. Documentary evidence of the works shall be submitted to and approved in writing by the Local Planning Authority prior to first use of the development.

Reason: To ensure the satisfactory development of the site and in the interests of protecting the amenity of neighbouring occupiers and to comply with saved Policies H5, and ENV2 of the Knowsley Replacement Unitary Development Plan, adopted June 2006 and Policy CS2 of the Core Strategy, adopted January 2016.

8. Contaminated Land

A. Risk Assessment

No development shall take place until an assessment of the risks posed by any contamination has been submitted to and approved in writing by the Local Planning Authority. This assessment must be undertaken by a suitably qualified contaminated land practitioner, in accordance with authoritative guidance (CLR 11), and shall assess any contamination on the site, whether or not it originates on the site.

Moreover, it must include (were relevant):

- (i) a survey of the extent, scale and nature of contamination;
- (ii) an assessment of the potential risks to:
 - human health,
 - property (existing or proposed) including buildings, crops, livestock, pets, woodland and
 - service lines and pipes,
 - adjoining land,
 - groundwaters and surface waters,
 - ecological systems,
 - archaeological sites and ancient monuments.

B. Submission of Remediation Scheme

Where land affected by contamination is found which poses unacceptable risks, no development shall take place until a detailed remediation scheme has been submitted to and approved in writing by the Local Planning Authority. The scheme must include an appraisal of remediation options, identification of the preferred option(s), the proposed remediation objectives and remediation criteria, and a description and programme of the works to be undertaken including the verification plan. As a minimum, the scheme must ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 in relation to its intended use.

C. Implementation of Approved Remediation Scheme

The approved remediation scheme shall be implemented and a verification report submitted to and approved in writing by the Local Planning Authority, prior to the development (or relevant phase of development) being brought into use.

D. Reporting of Unexpected Contamination

In the event that contamination is found at any time when carrying out the approved development that was not previously identified it must be reported immediately to the Local Planning Authority. Development on the part of the site affected must be halted and a risk assessment carried out and submitted to and approved in writing by the Local Planning Authority. Where unacceptable risks are found remediation and verification schemes shall be submitted to and approved in writing by the Local Planning Authority. These shall be implemented prior to the development (or relevant phase of development) being brought into use.

E. Materials Management Plan

Prior to the reuse of site won materials ('waste' and non-waste) a Materials Management Plan, signed off by a Qualified Person, shall be submitted to and agreed in writing with the local planning authority. The MMP shall demonstrate that any reuse of contaminated materials does not result in increased risk to the environment or human health.

F. Importation of Soil/Material

No soil (topsoil and subsoil) is to be imported to the site until it has been tested for contamination and assessed for its suitability for the proposed development; a suitable methodology for testing this material should be submitted to and agreed by the Local Planning Authority prior to the soils being imported onto site. The methodology should include the sampling frequency, testing schedules, criteria against which the analytical results will be assessed (as determined by the risk assessment) and source material information. The analysis shall then be carried out and evidence submitted to and approved in writing to by the Local Planning Authority.

Reason: In the interests of safety, to prevent pollution of the environment and to comply with Saved Policy ENV5 of the Knowsley Replacement Unitary Development Plan, adopted June 2006.

9. No part of the development hereby permitted shall be commenced until a Construction Management Plan has been submitted to and agreed in writing by the Local Planning Authority that details the means of mitigation of construction effects. This shall include but not be limited to the following: -

- oMethods for the mitigation of noise and vibration from building works, including any piling works, and also from the operation of any temporary power generation or pumping plant which will operate overnight.
- oMethods for dust control and suppression.

- oDetails of wheel washing facilities including location and type direction of vehicles to and from the site and process of accessing facilities.
- oThe areas for the storage of plant and materials.
- oLocation of site compound.
- oDetails of relevant pest control measures
- oDetails of hours of construction - No works shall take place outside the hours of:
 - a. 0800 to 1800 Monday to Friday (excluding Public Holidays)
 - b. 0800 to 1300 Saturday

All site works shall then proceed only in accordance with the approved management plan unless otherwise agreed in writing beforehand with the Local Planning Authority.

Reason: To ensure the satisfactory development of the site and in the interests of protecting the amenity of neighbouring occupiers and to comply with Policy CS2 in the Knowsley Local Plan Core Strategy January 2016 and saved Policy ENV2 of the Knowsley Replacement Unitary Development Plan, adopted June 2006.

10. Prior to the commencement of development, a lighting scheme, which includes the steps necessary to minimise light intrusion to the surrounding residential properties, shall be submitted for the written approval of the local planning authority. The scheme shall include an isolux plot to demonstrate that the obtrusive light limitations suggested in the relevant guidance are met.

All works which form part of the scheme shall be completed prior to operation and shall be maintained thereafter in accordance with the agreed scheme.

Reason: To ensure the satisfactory development of the site and in the interests of protecting the amenity of neighbouring occupiers and to comply with saved Policies H5, and ENV2 of the Knowsley Replacement Unitary Development Plan, adopted June 2006 and Policy CS2 of the Core Strategy, adopted January 2016.

11. Prior to the commencement of development, a biodiversity gain plan must be submitted to the local planning authority. The plan must include the following:
 - (a) information about the steps taken or to be taken to minimise the adverse effect of the development on the biodiversity of the onsite habitat and any other habitat,
 - (b) the pre-development biodiversity value of the onsite habitat,
 - (c) the post-development biodiversity value of the onsite habitat,
 - (d) any registered offsite biodiversity gain allocated to the development and the biodiversity value of that gain in relation to the development,
 - (e) any biodiversity credits purchased for the development, and
 - (f) such other matters as the Secretary of State may by regulations specify.
 The plan will be informed by a landscaping scheme (see condition 12). Development cannot commence until the biodiversity net gain plan has been approved by the local planning authority.

Reason: To comply with the Environment Act 2021.

12. Notwithstanding the details shown on the approved drawings, no part of the development shall be occupied until full details of both hard and soft landscaping works have been submitted to and approved in writing by the Local Planning Authority.

The details shall relate to all land surfaces not built upon and shall include:

- a) Land-levels and gradients resulting in the formation of any banks, terraces or other earthworks
- b) hard surfaced areas and materials,

- c) planting plans, specifications and schedules, planting size, species and numbers/densities, trees to be retained and a scheme for the timing / phasing of work.
- d) existing plants / trees to be retained
- e) A detailed regime for the ongoing and longer term maintenance of all soft landscaping is also required to be submitted for approval.

The approved landscaping works shall be implemented and completed prior to the occupation of the dwelling to which it relates unless otherwise agreed in writing by the Local Planning Authority.

Any trees or shrubs planted or retained in accordance with this condition which are removed, uprooted, destroyed, die or become severely damaged or become seriously diseased within 5 years of planting shall be replaced within the next planting season by trees or shrubs of similar size and species to those originally required to be planted.

Reason: To ensure that the site is satisfactorily landscaped having regard to its location and the nature of the proposed development and to comply with Saved Policy H5 of the Knowsley Replacement Unitary Development Plan, adopted June 2006, Policy CS19 of the Knowsley Local Plan Core Strategy, adopted January 2016, and the National Planning Policy Framework.

13. An undeveloped buffer (no hardstanding) of three metres in width must be retained at the northern boundary to protect the existing trees and landscaping.

Reason: To ensure that the proper protection of trees in the interests of visual amenity and to comply with Policies CS2 and CS19 of the Knowsley Local Plan Core Strategy, adopted January 2016 and saved Policy DQ4 of the Knowsley Replacement Unitary Development Plan, adopted June 2006.

SCHEDULE 1

Date Received	Ref. No	Version	Drawing/Document Title
14/10/2024	-	-	Location Plan
14/10/2024	PL02	-	Site Plan as Existing
14/10/2024	PL03	-	Site Plan as Proposed
14/10/2024	PL04	-	Plan as Proposed (Floor Plan)
14/10/2024	PL05	-	Elevations as Proposed Sheet 1
14/10/2024	PL06	-	Elevations as Proposed Sheet 2
14/10/2024	Sept 2024	-	Design and Access Statement

REASON(S) FOR THE GRANTING OF PLANNING PERMISSION

The decision to grant planning permission has also been taken having regard to the policies and proposals as set out below, and to all relevant material considerations including supplementary planning guidance:-

This informative is only intended as a summary of the reason(s) for the granting of planning permission. Should you require any further details relating to the decision please contact the relevant case officer (Jo Sheridan on 0151 443 2376)

ARTICLE 35 STATEMENT

The Local Planning Authority has acted positively and proactively in determining this application by identifying matters of concern within the application (as originally submitted) and negotiating with the applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal, in accordance with the presumption in favour of sustainable development, as set out within the National Planning Policy Framework.

NOTE FOR APPLICANT:

IMPORTANT - PLEASE READ CAREFULLY THE NOTES BELOW AS FAILURE TO COMPLY COULD MAKE THE DEVELOPMENT HEREBY PERMITTED UNAUTHORISED

- 1) This planning permission is granted in strict accordance with the approved plans. It should be noted however that:
 - a) Any variation from the approved plans following commencement of the development, irrespective of the degree of variation, will constitute unauthorised development and may be liable to enforcement action.
 - b) You or your agent or any other person responsible for implementing this permission should inform Planning Services immediately of any proposed variation from the approved plans and ask to be advised as to the best method to resolve the matter. Most proposals for variation to the approved plans will require the submission of a new planning application.
- 2) This permission is granted subject to conditions and it is the owner of the property and the person responsible for the implementation of the development who will be fully responsible for their compliance throughout the development and beyond.
- 3) If there is a condition that requires work to be carried out or details to be approved prior to the commencement of the development this is called a "condition precedent". The following should be noted with regards to conditions precedent.
 - a) If a condition precedent is not complied with prior to the start of development, the whole of the development will be unauthorised and you may be liable to enforcement action.
 - b) In addition, if the requirements of a condition precedent are subsequently not complied with, the development is unauthorised and the only way to rectify the development is the submission of a new application.

If any other type of condition is breached then you will be liable to a breach of condition notice.

- 2 Please refer to United Utilities letter dated 10th January 2025.
- 3 Please refer to Merseyside Fire & Rescue Service dated 7th January 2025.
- 4 4. The proposed development lies within an area that has been defined by the Mining Remediation Authority as containing coal mining features at surface or shallow depth. These features may include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and former surface mining sites. Although such features are seldom readily visible, they can often be present and problems can occur, particularly as a result of new development taking place.

Any form of development over or within the influencing distance of a mine entry can be dangerous and raises significant land stability and public safety risks. As a general

precautionary principle, the Mining Remediation Authority considers that the building over or within the influencing distance of a mine entry should be avoided. In exceptional circumstance where this is unavoidable, expert advice must be sought to ensure a suitable engineering design which takes account of all relevant safety and environmental risk factors, including mine gas and mine-water. Your attention is drawn to the Mining Remediation Authority Policy in relation to new development and mine entries available at: Building on or within the influencing distance of mine entries - GOV.UK

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Mining Remediation Authority Permit. Such activities could include site investigation boreholes, excavations for foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Application forms for Mining Remediation Authority permission and further guidance can be obtained from The Mining Remediation Authority's website at: www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property

What is a permit and how to get one? - GOV.UK (www.gov.uk)

In areas where shallow coal seams are present caution should be taken when carrying out any on site burning or heat focused activities.

If any future development has the potential to encounter coal seams which require excavating, for example excavation of building foundations, service trenches, development platforms, earthworks, non-coal mineral operations, an Incidental Coal Agreement will be required. Further information regarding Incidental Coal Agreements can be found here - <https://www.gov.uk/government/publications/incidental-coal-agreement/guidance-notes-for-applicants-for-incidental-coal-agreements>

If any coal mining feature is encountered during development, this should be reported immediately to the Mining Remediation Authority on 0345 762 6846 or if a hazard is encountered on site call the emergency line 0800 288 4242. Further information is available on the Mining Remediation Authority website at: Mining Remediation Authority - GOV.UK

Informative Note valid from 1st January 2025 until 31st December 2026



Executive Director - Regeneration and Economic Development

Date: 31 January 2025

IMPORTANT NOTES FOR YOUR ATTENTION:

1. This permission refers only to that required under the Town and Country Planning Acts and does not include any consent or approval under any other enactment, bylaw, order or regulation.
2. This permission refers only to those plans submitted as part of the Planning Application a copy of which is retained by the Local Planning Authority. The Local Planning Authority should be contacted in writing if it is proposed to amend these plans in any way as a further permission, may be required.
3. You should ensure that you understand the requirements of all planning conditions and that you fully comply with their requirements. If you are in any doubt about what a condition requires of you, please ask us for assistance. Planning conditions may require you to submit further information to us and await our approval before you can start your development. A failure to do so could result in your development being unlawful and necessitate the submission of a further planning application. A failure to comply with the conditions of the permission/consent may result in the taking of enforcement and potentially legal action, against you to remedy the breach of planning control.
4. A fee is normally payable to discharge planning conditions in accordance with government regulations.
5. This permission does not convey any rights or approval to build on, or develop, any land that is not fully owned or controlled by you, including on party boundaries. You should satisfy yourself that the agreement of any adjoining landowners has been given prior to commencing any building works.
6. If a Building Regulations Consent is required for these works it is your responsibility to ensure that the plans submitted for both the Building Regulations Consent and Planning Permission are the same in all respects. Should the plans relating to one consent vary from the other, it will be necessary for you to submit amended plans to this Department and obtain the relevant approval(s) prior to commencing any works. Knowsley Council's Building Control team are contactable on (0151)-443 2342 and they would be pleased to assist you.

Appeals to the Secretary of State

- If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.
- As this is a decision for a minor commercial application, if you want to appeal against your local planning authority's decision then you must do so within 12 weeks of the date of this notice.
- Appeals can be made online at: <https://www.gov.uk/planning-inspectorate>.
If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.
- The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.
- The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

Knowsley Council
By email

Your ref: 24/00554/FUL
Our ref: DC/25/67
Date: 10-JAN-25

Dear Planning Team

Location : Pilkington Court Sinclair Way Prescott Business Park Prescott Knowsley L34 1QG
Proposal : ERECTION OF A STORAGE/WAREHOUSE BUILDING (USE CLASS B8) AND ASSOCIATED CAR PARKING

United Utilities provides the following comments to support the Local Planning Authority in their determination of the planning application detailed above, and to direct the applicant to further sources of support and guidance on matters that might impact their proposal.

The letter and Appendix should be read in their entirety to support the determination, the design, and should the scheme be approved, the subsequent delivery of the proposal.

DRAINAGE

We request the following drainage condition is attached to any subsequent approval:

CONDITION

Prior to the commencement of development, details of a sustainable surface water drainage scheme and a foul water drainage scheme shall be submitted to and approved in writing by the Local Planning Authority. The drainage schemes must include:

- (i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include evidence of an assessment of ground conditions and the potential for infiltration of surface water in accordance with BRE365;***
- (ii) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations);***
- (iii) Levels of the proposed drainage systems including proposed ground and finished floor levels in AOD;***
- (iv) Incorporate mitigation measures to manage the risk of sewer surcharge where applicable; and***
- (v) Foul and surface water shall drain on separate systems.***

The approved schemes shall also be in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards.

Prior to occupation of the proposed development, the drainage schemes shall be completed in accordance with the approved details and retained thereafter for the lifetime of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution.

Please note, United Utilities is not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as a main river).

To discuss their drainage proposals the applicant should contact our **Developer Services** team by email at SewerAdoptions@uuplc.co.uk. Alternative ways to contact the team are detailed in the Appendix, Section 4.0 'Contacts'.

When considering their drainage proposal, the applicant should investigate the existence of any pipelines and/or apparatus that might impact their detailed design (see Section 'UNITED UTILITIES' PROPERTY, ASSETS AND INFRASTRUCTURE').

United Utilities will not carry out an assessment on the acceptability of submitted drainage proposals in relation to our water pipelines when responding to a planning application. It is the applicant's responsibility to ensure that any detailed drainage plans comply with our 'Standard Conditions for Works Adjacent to Pipelines' which can be found on our website: [Working near our pipes - United Utilities](#). Failure to consider existing pipelines when designing a drainage proposal may result in the applicant having to redesign proposals at a later date.

Management and maintenance of Sustainable Drainage Systems (SuDS)

Without effective management and maintenance SuDS can fail or become ineffective which may have a detrimental impact on the surrounding area. There is also a risk ineffective SuDS could impact the performance of the public sewer network where the two systems interact. Therefore, when SuDS is included in a proposed development, we recommend the Local Authority include a condition relating to SuDS management and maintenance in any subsequent Decision Notice. We provide an example condition below that may be suitable in many circumstances.

Prior to occupation of the development a sustainable drainage management and maintenance plan for the lifetime of the development shall be submitted to the local planning authority and agreed in writing. The sustainable drainage management and maintenance plan shall include as a minimum:

- (i) Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a resident's management company; and***

- (ii) *Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime.*

The development shall subsequently be completed, maintained and managed in accordance with the approved plan.

Reason: To ensure that management arrangements are in place for the sustainable drainage system in order to manage the risk of flooding and pollution during the lifetime of the development.

Please note United Utilities cannot provide comment on an asset that is owned by a third-party management and maintenance company. Therefore, whilst we recommend the inclusion of a management and maintenance condition, United Utilities would not be involved in its discharge.

UNITED UTILITIES' PROPERTY, ASSETS AND INFRASTRUCTURE

It is the applicant's responsibility to investigate the existence of any pipelines that might cross or impact their proposed site and also to demonstrate the exact relationship between United Utilities' assets and the proposed development. The applicant should not rely solely on the detail contained within asset maps when considering a proposed layout.

It is important that the supporting information contained in the Appendix, Section 2.0 'United Utilities' Property, Assets and Infrastructure', is read in conjunction with this letter. This provides information that might impact a proposed layout and additional guidance that an applicant or developer must consider when United Utilities assets are located in, or in the locality of, the proposed site.

Where United Utilities' assets exist, it is essential that the applicant, or any subsequent developer, contacts our Developer Services team prior to commencing any works on site, including trial holes, groundworks or demolition. See Appendix, Section 4.0 'Contacts'

WATER EFFICIENCY IN NEW DEVELOPMENT

Local planning authorities have the option to set additional technical requirements in respect of water use for the construction of new build dwellings, exceeding the minimum standards required by Building Regulations. All new homes are required to meet the mandatory national standard of 125 litres of water used per person per day as set out in Building Regulations Approved Document G. Where there is a clear local need, a local planning authority's development plan policies can require new-build dwellings to meet the tighter Building Regulations optional requirement of 110 litres of water used per person per day. If your adopted development plan includes a policy that implements the tighter water efficiency standard for new-build dwellings in Part 3 of Building Regulations, you should ensure that this is a condition of any planning permission you may grant. You should also consider whether there is any adopted development plan policy relating to a water efficiency in the construction of non-residential development. As this is a matter for the local planning authority / building control

body, United Utilities would not be involved in the discharge of conditions relating to water efficiency.

We request that a copy of this letter and the Appendix is made available to the applicant.

Yours faithfully

The Planning, Landscape and Ecology Team

APPENDIX:

Supporting information for the decision maker, applicant, developers and any other interested party

Whilst we provide the following information to support the design and delivery of the proposed scheme, we strongly recommend that the applicant, or any subsequent developer, contacts our Developer Services team at the earliest opportunity, using our **free pre-development enquiry service**, to ensure they have fully considered all aspects of development and to avoid any potential issues or unexpected costs at a later date.

Full details of the services offered to developers, guidance and application forms are available on our website: www.unitedutilities.com/builders-developers/

1.0 DRAINAGE DESIGN

1.1 The importance of sustainable drainage systems

We strongly encourage all developments to include sustainable drainage systems to help manage surface water and to offer new opportunities for wildlife to flourish. We request that Local Planning Authorities and applicants do all they can to avoid surface water entering the public sewer. The flows that come from this surface water are very large when compared with the foul water that comes from toilets, showers, baths, washing machines, etc. It is the surface water that uses up a lot of capacity in our sewers and results in the unnecessary pumping and treatment of surface water at our pumping stations and treatment works. If new developments can manage flows through sustainable drainage systems that discharge to an alternative to the public sewer, it will help to minimise the likelihood of sewers spilling into watercourses and the flooding of homes and businesses.

1.2 Adoption and construction of drainage systems

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, their proposed detailed design will be subject to a technical appraisal by our Developer Services team and must meet the requirements outlined in 'Sewerage Sector Guidance Appendix C – Design and Construction Guidance v2-2' dated 29 June 2022 or any subsequent iteration. This is important as drainage design can be a key determining factor of site levels and layout.

If the proposal incorporates a SuDS component(s) which interacts with a sewer network that may be offered for adoption by United Utilities we recommend the applicant seeks further advice regarding the SuDS design; detailed information is available on our website.

Our acceptance of any drainage strategy submitted by an applicant to the Local Planning Authority for approval does not infer that a detailed drainage design will meet the requirements for a successful adoption application. **We strongly recommend that no construction commences until the detailed drainage design has been submitted directly to United Utilities, assessed and accepted in writing. Any work carried out prior to the technical assessment being approved is done entirely at the developer's own risk and could be subject to change.**

2.0 UNITED UTILITIES' PROPERTY, ASSETS AND INFRASTRUCTURE

2.1 Water pipelines

United Utilities will not allow building over or in close proximity to a water main.

For any works in the vicinity of water pipelines, the applicant must comply with our 'Standard Conditions for Works Adjacent to Pipelines', which can be found on our website: <https://www.unitedutilities.com/builders-developers/your-development/planning/building-over-or-working-near-our-assets/working-near-our-pipes/>

2.2 Wastewater pipelines

United Utilities will not allow a new building to be erected over or in close proximity to a public sewer or any other wastewater pipeline. This will only be reviewed in exceptional circumstances.

Nb. Proposals to extend domestic properties either above, or in close proximity to a public sewer will be reviewed on a case by case basis by either by a building control professional or following a direct application to United Utilities (see our website for further details).

2.3 Water and wastewater pipelines and apparatus

A number of providers offer a paid for mapping service, including United Utilities (see Section 4.0 'Contacts' (below)). The position of the underground apparatus shown on water and wastewater asset maps is approximate only and is given in accordance with the best information currently available. Therefore, we strongly recommend the applicant, or any future developer, does not rely solely on the asset maps to inform decisions relating to the detail of their site and instead investigates the precise location of any underground pipelines and apparatus. Where additional information is requested to enable an assessment of the proximity of proposed development features to United Utilities assets, the proven location of pipelines should be confirmed by site survey; an extract of asset maps will not suffice. The applicant should seek advice from our Developer Services team on this matter. See Section 4.0. 'Contacts' (below). United Utilities Water will not accept liability for any loss or damage caused by the actual position of our assets and infrastructure being different from those shown on asset maps.

Developers should investigate the existence and the precise location of water and wastewater pipelines as soon as possible as this could significantly impact the preferred site layout and/or diversion of the asset(s) may be required. Unless there is specific provision within the title of the property or an associated easement, any necessary disconnection or diversion of assets to accommodate development, will be at the applicant/developer's expense. In some circumstances, usually related to the size and nature of the assets impacted by proposals, developers may discover the cost of diversion is prohibitive in the context of their development scheme.

Any agreement to divert our underground assets will be subject to a diversion application, made directly to United Utilities. This is a separate matter to the determination of a planning application. We will not guarantee, or infer acceptance of, a proposed diversion through the planning process (where diversion is indicated on submitted plans). In the event that an application to divert or abandon underground assets is submitted to United Utilities and

subsequently rejected (either before or after the determination of a planning application), applicants should be aware that they may need to amend their proposed layout to accommodate United Utilities' assets.

Where United Utilities' assets exist, the level of cover to United Utilities pipelines and apparatus must not be compromised either during or after construction and there should be no additional load bearing capacity on pipelines without prior agreement from United Utilities. This would include sustainable drainage features, earth movement and the transport and position of construction equipment and vehicles.

Any construction activities in the vicinity of United Utilities' assets, including any assets or infrastructure that may be located outside the applicant's red line boundary, must comply with national building and construction standards and where applicable, our 'Standard Conditions for Works Adjacent to Pipelines', which can be found on our website: <https://www.unitedutilities.com/builders-developers/your-development/planning/building-over-or-working-near-our-assets/working-near-our-pipes/>.

The applicant, and/or any subsequent developer should note that our 'Standard Conditions' guidance applies to any design and construction activities in close proximity to water pipelines and apparatus that are no longer in service, as well as pipelines and apparatus that are currently in operation.

It is the applicant's responsibility to ensure that United Utilities' required access is provided within any proposed layout and that our infrastructure is appropriately protected. The developer would be liable for the cost of any damage to United Utilities' assets resulting from their activity.

3.0 WATER AND WASTEWATER SERVICES, METERING AND CHARGES

If the applicant intends to receive water and/or wastewater services from United Utilities they should visit our website or contact the Developer Services team for advice at the earliest opportunity. This includes seeking confirmation of the required metering arrangements for the proposed development. See Section 4.0 'Contacts' (below).

If the proposed development site benefits from existing water and wastewater connections, the applicant should not assume that the connection(s) will be suitable for the new proposal or that any existing metering arrangements will suffice. In addition, if reinforcement of the water network is required to meet potential demand, this could be a significant project and the design and construction period should be accounted for.

In some circumstances a water meter must be installed to premises. Detailed guidance on whether the development will require a compulsory meter is available on our website within our published Charges Schemes; [Our charges 2024/25 | United Utilities](#) (Section 8.7) or [Our charges 2023/24 | United Utilities](#) (Section 7.7).

To promote sustainable development United Utilities offers a reduction in infrastructure charges to applicant's delivering water efficient homes and draining surface water sustainably (criteria applies). For further information, we strongly recommend the applicant visits our website when

considering any water or wastewater design <https://www.unitedutilities.com/builders-developers/your-development/planning/building-sustainable-homes/>
Business customers can find additional information on our sustainable drainage incentive scheme at <https://www.unitedutilities.com/Business-services/retailers/incentive-schemes/>

To avoid any unnecessary costs and delays being incurred by the applicant or any subsequent developer, we strongly recommend the applicant seeks advice regarding water and wastewater services and metering arrangements, at the earliest opportunity. See Section 4.0 'Contacts' (below).

4.0 CONTACTS

For advice on your development contact our **DEVELOPER SERVICES** team as follows:

Website (including 'Live Chat'): <http://www.unitedutilities.com/builders-developers.aspx>

Email:

WATER (water mains, supply and metering):	DeveloperServicesWater@uuplc.co.uk
WASTEWATER (public sewers and drainage):	SewerAdoptions@uuplc.co.uk
SLUDGE PIPELINES:	DeveloperServicesWater@uuplc.co.uk

Telephone (Monday-Friday, 8am-6pm): **0345 072 6067**

PROPERTY SEARCHES (FOR ASSET MAPS):

A number of providers offer a paid for mapping service including United Utilities. For more information, or to purchase a sewer and water plan from United Utilities, please visit <https://www.unitedutilities.com/property-searches/>

Water and sewer records can be viewed for free at our Warrington Head Office by calling 0370 751 0101. Appointments must be made in advance. Public sewer records can be viewed at local authority offices. Arrangements should be made directly with the local authority.

UNITED UTILITIES LEGAL SERVICES (FOR EASEMENT DOCUMENTS):

Copies of relevant deeds may be purchased from United Utilities Legal Services. This information is also available from Land Registry.

To purchase a copy of easement documents from United Utilities, please email: LegalServices@uuplc.co.uk

Knowsley MBC
Planning Department
Municipal Buildings
Archway Road
Huyton
L36 9YU

Email:
dcconsultations@knowsley.gov.uk

**Merseyside Fire & Rescue Authority
Community Fire Protection**

Fire Engineering Team
Service Headquarters
Bridle Road
Bootle
Merseyside
L30 4YD

Telephone: 0151 296 6590 (Calls may be recorded)
Inspecting Officer: Rachel Holland
Email: fireengineeringteam@merseyfire.gov.uk
web Site: www.merseyfire.gov.uk

Your ref: 24/00554/FUL

Our ref:00499295/1254623/RH/LD

Date:7th January 2025

Dear Sir/Madam,

THE TOWN AND COUNTRY PLANNING ACT 1990
PLANNING APPLICATION NUMBER REF: 24/00554/FUL
PROPOSAL: ERECTION OF A STORAGE/WAREHOUSE BUILDING (USE CLASS B8)
AND ASSOCIATED CAR PARKING
ADDRESS: Pilkington Court Sinclair Way Prescott Business Park

The Fire Authority requests that any decision notice includes the following information:

The plans relating to the above application have been examined and below are the Fire Authority's observations:

Access for Fire Fighting

- Access for fire appliances should comply with the requirements of Section B5, Schedule 1 of the Building Regulations. Provisions for access will depend on the size and use of the building. The design of the access route, for example minimum road widths and maximum reversing distances, should also be considered (Appendix A, attached).
- In accordance with Section 55 of the County of Merseyside Act 1980, the position of the premises should not compromise or impede existing means of fire service access to a neighbouring building.

Water Provision


- Water supplies for firefighting purposes should be risk assessed in accordance with the undermentioned guidance in liaison with the water undertakers (United Utilities - 0161 907 7351) with suitable and sufficient fire hydrants supplied.
- Consideration should be given to the recommendations within the 'National guidance document on the provision of water for firefighting', produced by the Local Government Association and Water UK, available for free download via: <https://www.water.org.uk/wp-content/uploads/2018/11/national-guidance-document-on-water-for-ffg-final.pdf>

Further information regarding access requirements can be found in the current version of Approved Document B, which is available for free download via:

<https://www.gov.uk/government/publications/fire-safety-approved-document-b>

Should you require any further information in respect of this correspondence please contact the Officer named above.

Yours faithfully

A handwritten signature in black ink, appearing to read 'R. Holland'.

Rachel Holland

Authorised Fire Safety Inspecting Officer
And on behalf of Merseyside Fire and Rescue Authority

Appendix A - Access and Facilities for the Fire Service as given in Section B5 of Approved Document B

Domestic Dwellings

For dwelling houses, access for a pumping appliance should be provided to within 45m of all points inside the dwelling house.

For flats, either: access for a pumping appliance should be provided to within 45m of all points inside each flat of a block, measured along the route of the hose; or fire mains should be provided.

Commercial Buildings

Small buildings (up to 2000m², with a top occupied storey a maximum of 11m above ground level), require access for a pump appliance to 15% of the perimeter, or within 45m of every point of the footprint of the building, whichever is the less onerous.

Larger buildings will require access to a percentage of the perimeter that increases incrementally with size of the total floor area and height of building – please see details in Approved Document B Volume 2 Section 15.

Elevations to which vehicle access is provided will require a door, to give access into the building. The maximum distance between doors, or between a door and the end of the elevation, is 60m (i.e. a 150m elevation would need a minimum of two doors).

All Buildings

Access routes and hardstanding should comply with Table 13.1 ADB Volume 1 / Table 15.2 ADB Volume 2. Please note: MFRS appliances are 17 tonnes (pump) and 26 tonnes (high reach).

Dead-end access routes longer than 20m require turning facilities (e.g. a turning circle or hammer head, or other turning point).

Where fire mains are fitted, access should be provided for a pumping appliance to within 18m of each fire main inlet connection point. Inlets should be on the face of the building and visible from the parking position of the appliance. The run of horizontal internal connecting pipe should be a maximum of 18m in length.

Buildings with a storey more than 18m above the fire service vehicle access level, or a basement more than 10m below, should have one or more firefighting shafts containing fire-fighting lifts and fire mains (a minimum of two fire-fighting shafts will be required for buildings with a floor area of 900 m² or more).

Buildings in the 'shop and commercial', 'assembly and recreation' or 'industrial' purpose groups (Groups 4, 5, or 6), with a storey area of 900m² or more and a storey height of 7.5m or more above fire service vehicle access level will require at least two firefighting shafts (firefighting lifts may not be needed).

Entry to a firefighting shaft at fire service access level should be available either directly from the open air or by way of a protected corridor not exceeding 18m in length. The corridor is deemed to be part of the firefighting shaft, and any access to it from the accommodation should be by way of protected lobbies.

Hydrants

Where a building has a compartment with an area of more than 280m² and is being erected more than 100m from an existing fire hydrant, additional hydrants are required as follows:

Buildings with fire main – hydrant within 90m of dry fire main inlet;

Buildings without fire main – hydrant within 90m of an entrance to the building; and a maximum of 90m apart.