

<u>APPLICATION NO:</u>	23/00194/CLD	<u>CASE OFFICER:</u>	Reece Black
<u>WARD:</u>	Northwood	<u>PARISH:</u>	
<u>LOCATION:</u>	22 Quernmore Road, Northwood, Kirkby		
<u>PROPOSAL:</u>	CERTIFICATE OF LAWFUL DEVELOPMENT FOR PROPOSED SINGLE STOREY REAR EXTENSION		

Site Description

The application site is located at 22 Quernmore Road, Northwood and is located in an area that is allocated as a Primarily Residential Area in the Development Plan. The property is a semi-detached dwelling and is brick facing on its front, side and rear elevations. It features white UPVC openings and grey, flat, interlocking roof tiles.

Proposal

The application seeks a Certificate of Lawfulness for the erection of a single storey rear extension.

The proposed rear extension would have a projection of 2.93m and would have a width of 4.76m. The proposal would be served by a flat roof, which the eaves would measure at a height of 2.89m and the highest point (parapet capping) would measure at a height of 3.10m.

Consultations

None Required

Representations

Not applicable.

Planning History

No recorded planning history.

Assessment

The application seeks confirmation that the development is 'permitted development' under the Town & Country Planning (General Permitted Development) (England) Order 2015.

Class A states that an enlargement, improvement or alteration of a house of a house is permitted development provided that the development does not:

- b) The total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage;
- c) The height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

- d) The height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the dwellinghouse;
- e) The enlarged part of the dwellinghouse would extend beyond a wall which – forms the principal elevation of the original dwellinghouse; or fronts a highway and forms a side elevation of the original dwellinghouse;
- f) Subject to paragraph (g), have a single storey and – extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or exceed 4 metres in height;
- g) For a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, would have a single storey and – extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or exceed 4 metres in height;
- h) would have more than a single storey and – extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;
- i) would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;
- j) would extend beyond a wall forming a side elevation of the original dwellinghouse, and would – exceed 4 metres in height, have more than a single storey, or have a width greater than half the width of the original dwellinghouse;
- k) include a veranda, balcony, raised platform of a flue;
- l) lie in a conservation area

Development is permitted by Class A subject to the following conditions:

- a) The materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;
- b) Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be – obscure-glazed, and non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

The proposed rear extension would not project more than 4m from the rear elevation of the original dwellinghouse, would not exceed 4m in height and the height of the eaves of the extension would not exceed 3m.

The rear extension would therefore comply with the requirements of Class A of Part 1, Schedule 2 of the Town and Country Planning Act (General Permitted Development) (England) Order 2015 (as amended).

Conclusion

It is concluded that the proposal complies with Class A of Part 14, Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended). Accordingly, it is recommended that the certificate of Lawful Development for the proposed development be granted.

Recommendation

That a certificate of Lawful Development be granted.

1. The proposal complies with the requirements of Class A of Part 14, Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

SCHEDULE 1

Date Received	Ref. No	Version	Drawing/Document Title
31/03/2023	011-002	-	PROPOSED FLOOR PLANS AND LOCATION PLAN
31/03/2023	011-004	-	PROPOSED ELEVATIONS

Signed Case Officer¹:

Reece Black

**Signed Authorising
Officer²:**

K Foster

Date:

23 May 2023

¹ I confirm that I do not have a personal relationship with the applicant, agent or other interested parties; I also confirm that I do not have a financial interest in the site or the development proposed

² I confirm that I do not have a personal relationship with the applicant, agent or other interested parties; I also confirm that I do not have a financial interest in the site or the development proposed