



- GENERAL NOTES
1. 100mm DIA DUCT C/W SLOW BEND FOR VIRGIN MEDIA
 2. 150mm DIA DUCT C/W SLOW BEND FOR INCOMING ELECTRIC
 3. 2x 150mm DIA DUCT C/W SLOW BEND FOR ECC AND CAR PARK LIGHTING
 4. 100mm DIA DUCT C/W SLOW BENDS AND DRAW ROPE (SPARE)
 5.  400mm x 400mm INSPECTION CHAMBER. CENTURIAN DRAW CHAMBERS AS SUPPLIED BY COOPER CLARKE GROUP LTD TEL. 01483 428 106 (OR EQUAL & APPROVED) DOUBLE UNIT REF CU4/2LP, CLEAR OPENING 450mm x 450mm, UNIT DEPTH 640mm THE CHAMBERS SURROUNDED BY 150mm THICK 15N/mm2 CONCRETE, SHALL SATISFY B125 (125Kn), VERTICAL LOAD CLASSIFICATION. TO BE CONSTRUCTED IN ACCORDANCE WITH MANUFACTURERS WRITTEN INSTRUCTIONS FRAME / COVER TYPE AND EXACT DEPTH OF CHAMBER TO BE CONFIRMED BY CPPIc.
 6. ALL BUILDERS WORK BY MAIN CONTRACTOR.
 7. ALL WORKS IN FULL COMPLIANCE WITH BS7671 18TH EDITION.

PRELIMINARY ISSUE

P01		06.02.25	Preliminary issue.
Rev	Date	Description	
Project - Countryside Properties Lickers Lane, Halsnead Whiston			
Title - Proposed Site Plan			
Scale - 1:100 @ A1		Design by - KJ	
Date - 05.02.25		Cad by - EB	
Drawing No. - 6323-KGA-00-00-DR-E-0300			Revision - P01

KGA (UK) Ltd
Chartered Building Services
Consulting Engineers
Trinity Chambers
10 Ivy Street
Birkenhead
Merseyside
CH41 5EF

T: 0151 647 5021
E: eng@kga.co.uk
W: www.kga.co.uk

