



- GENERAL NOTES**
1. 100mm DIA DUCT CW SLOW BEND FOR VIRGIN MEDIA
 2. 150mm DIA DUCT CW SLOW BEND FOR INCOMING ELECTRIC
 3. 2x 100mm DIA DUCT CW SLOW BEND FOR ECC AND CAR PARK LIGHTING
 4. 100mm DIA DUCT CW SLOW BENDS AND DRAIN ROPE (SPARE)
 5. 400mm x 400mm INSPECTION CHAMBER.
- CENTURIAN DRAW CHAMBERS
AS SUPPLIED BY COOPER CLARKE GROUP LTD TEL. 01483 426 106 (OR EQUAL & APPROVED)
DOUBLE UNIT REF CU42LP - CLEAR OPENING 450mm x 450mm. UNIT DEPTH 640mm
- THE CHAMBERS SURROUNDED BY 150mm THICK 15N/mm² CONCRETE, SHALL SATISFY B125 (125KN), VERTICAL LOAD CLASSIFICATION, TO BE CONSTRUCTED IN ACCORDANCE WITH MANUFACTURERS WRITTEN INSTRUCTIONS FRAME, COVER TYPE AND EXACT DEPTH OF CHAMBER TO BE CONFIRMED BY CPIC.
6. ALL BUILDERS WORK BY MAIN CONTRACTOR.
 7. ALL WORKS IN FULL COMPLIANCE WITH BS7671 18TH EDITION.

PRELIMINARY ISSUE

P02	31.05.25	Inspection chamber and luminaires indicated
P01	06.02.25	Preliminary issue.

Rev	Date	Description
-----	------	-------------

Project - **Countryside Properties
Lickers Lane,
Halshead
Whiston**

Title - **Proposed Site Plan**

Scale - 1:100 @ A1 Design by - KJ

Date - 05.02.25 Cad by - EB

Drawing No. -	Revision -
6323-KGA-00-00-DR-E-0300	P02

KGA (UK) Ltd
Chartered Building Services
Consulting Engineers
Trinity Chambers
10 Ivy Street
Birkenhead
Merseyside
CH41 5EF

T: 0151 647 5021
E: eng@kga.co.uk
W: www.kga.co.uk

Constructionline

ISO 9001
REGISTERED 7584

UKAS
MANAGEMENT SYSTEMS
955

ISO 14001
REGISTERED 7584