



- GENERAL NOTES
- 100mm DIA DUCT C/W SLOW BEND FOR VIRGIN MEDIA
 - 150mm DIA DUCT C/W SLOW BEND FOR INCOMING ELECTRIC
 - 2x 150mm DIA DUCT C/W SLOW BEND FOR ECC AND CAR PARK LIGHTING
 - 100mm DIA DUCT C/W SLOW BENDS AND DRAW ROPE (SPARE)
 - 400mm x 400mm INSPECTION CHAMBER.
CENTURIAN DRAW CHAMBERS
AS SUPPLIED BY COOPER CLARKE GROUP LTD TEL. 01483 428 106 (OR EQUAL & APPROVED)
DOUBLE UNIT REF CU4/2LP, CLEAR OPENING 450mm x 450mm, UNIT DEPTH 640mm
THE CHAMBERS SURROUNDED BY 150mm THICK 15N/mm² CONCRETE, SHALL SATISFY B125 (125Kn), VERTICAL LOAD CLASSIFICATION. TO BE CONSTRUCTED IN ACCORDANCE WITH MANUFACTURERS WRITTEN INSTRUCTIONS FRAME / COVER TYPE AND EXACT DEPTH OF CHAMBER TO BE CONFIRMED BY CPPIc.
 - ALL BUILDERS WORK BY MAIN CONTRACTOR.
 - ALL WORKS IN FULL COMPLIANCE WITH BS7671 18TH EDITION.

PRELIMINARY ISSUE

P02	24.06.25	Inspection chamber and luminaire relocated
P01	06.02.25	Preliminary issue.
Rev	Date	Description

Project -
Countryside Properties
Lickers Lane,
Halsnead
Whiston

Title -
Proposed Site Plan

Scale - 1:100 @ A1 Design by - KJ

Date - 05.02.25 Cad by - EB

Drawing No. -	Revision -
6323-KGA-00-00-DR-E-0300	P02

KGA (UK) Ltd
Chartered Building Services
Consulting Engineers
Trinity Chambers
10 Ivy Street
Birkenhead
Merseyside
CH41 5EF



T: 0151 647 5021
E: eng@kga.co.uk
W: www.kga.co.uk

