



Powell Tolner & Associates Ltd

FLOOD RISK ASSESSMENT & DRAINAGE STRATEGY

Project: Image Business Park, Acornfield Road, Knowsley Site 2

PTA Project No: 9685

Document Ref: 9685-FRA & Drainage Strategy

Status: For Planning

Revision: P02

Date: December 2021

Client: Knowsley (Image Business Park) Ltd



Issued by

PTA
29 Red Lion Street
Chesham
Buckinghamshire
United Kingdom
HP5 1EJ
Tel: + 44 1494 772721
central@ptaconsult.co.uk

	Name	Position	Signature	Date
Prepared by:	George Westgarth	Project Engineer	GW	14.12.2021
Reviewed by:	Alex Herman	Director	AH	14.12.2021
For and on behalf of Powell Tolner & Associates Limited				

Revision	Date	Description	Prepared	Reviewed
P01	14.12.21	Issued for comment	GW	AH
P02	16.12.21	Drainage Strategy Updated	GW	SLW

This report has been produced by Powell Tolner & Associates Ltd for exclusive use by the client named on the document. This report may not be relied upon by any other party without written consent from Powell Tolner & Associates Ltd. Powell Tolner & Associates Ltd accept no liability for any costs, liabilities or losses arising as a result of the use or reliance upon the contents of this report by any person other than the named client.

All comments and conclusions in this report are based on our reliance on that the sourced data and Powell Tolner & Associates Ltd accept no liability for any inaccuracy in that information.

©This report is the copyright of PTA.

Any unauthorised reproduction or usage by any person other than the addressee is strictly prohibited.

TABLE OF CONTENTS

1	INTRODUCTION	1
2	DEVELOPMENT DESCRIPTION	2
2.1	Location	2
2.2	Existing Site	3
2.3	Proposals.....	3
2.4	Flood Vulnerability Classification	4
2.5	Flood Zone Compatibility.....	4
3	FLOOD RISK	5
3.1	Rivers	5
3.2	Tidal	5
3.3	Ground Water	5
3.4	Overland Flows.....	6
3.5	Sewers.....	8
3.6	Other Sources.....	8
3.7	Climate Change	9
3.8	Residual Risk.....	9
4	FLOOD RISK MANAGEMENT	10
4.1	Floor Levels	10
4.2	Sustainable Drainage Techniques	10
4.2.1	Living Roofs	10
4.2.2	Basins and Ponds.....	11
4.2.3	Filter Strips and Swales.....	11
4.2.4	Infiltration Devices	11
4.2.5	Attenuation Tank.....	11
4.2.6	Permeable Paving/Porous Asphalt.....	11
4.2.7	Rainwater Harvesting Systems.....	12
4.2.8	Exceedance Event.....	12
4.2.9	Surface Water Treatment	12
4.3	Surface Water Management.....	14
4.3.1	Greenfield Runoff Assessment.....	14
4.3.2	Post-Development Surface Water Run-off	14
4.3.3	Proposed Foul Water Drainage	15
5	OFFSITE IMPACT	16
6	MAINTENANCE STRATEGY	17

6.1	Manholes, Inspection Chambers, Pipe Work, Drainage Channels & Gullies	17
6.2	Vortex Flow Control (Hydrobrake)	18
6.3	Proprietary Surface Water Treatment Systems	19
7	CONCLUSION	22
	APPENDICES	23
	Appendix A – Topographical Survey Plan	24
	Appendix B – Proposed Site Layout	25
	Appendix C – Public Sewer Asset Plan	26
	Appendix D – Exceedance Flow Path Plan	27
	Appendix E – Existing Runoff Calculations	28
	Appendix F – MicroDrainage Output Files	29
	Appendix G – Proposed Drainage Strategy	30
	Appendix H – Borehole Logs	31
	Appendix I – SuDS Proforma	32

Figures

Figure 1: Site Location (Google Maps © 2021 Bluesky)	2
Figure 2: Aerial Photo (Google Maps © 2021 Bluesky)	3
Figure 3: EA Flood Map	4
Figure 4: Watercourse Location	5
Figure 5: Boreholes' Location	6
Figure 6: EA Surface Water Flood Risk Map	7
Figure 7: EA Surface Water Flood Risk Map - Flood Depth in High Risk Scenario	7
Figure 8: EA Surface Water Flood Risk Map - Flood Velocity in High Risk Scenario	8
Figure 9: EA Reservoirs Flood Risk Map	9

Table

Table 1: Existing Areas	3
Table 2: Proposed Areas	4
Table 3: SuDS Hierarchy	10
Table 4: SuDS Pollution Indices	13
Table 5: SuDS Mitigation Indices	13
Table 6: Existing Flow Rates	14
Table 7: Existing and Proposed Discharge Rates	15
Table 8: Operation & maintenance requirements for pipe network, manholes & inspection chambers, drainage channels & gullies	17
Table 9: Operation & maintenance requirements for Vortex Flow Controls	18
Table 10: Operation & maintenance for proprietary surface water treatment systems	19
Table 11: Operation & maintenance for Attenuation Tanks	20
Table 12: Operations & maintenance for Porous Paved Areas	21

1 INTRODUCTION

Powell Tolner and Associates Limited (PTA) have been commissioned by Knowsley (Image Business Park) Ltd to produce a Flood Risk Assessment (FRA) and Drainage Strategy report in order to support the planning application for a proposed industrial development onto a partially greenfield and brownfield site at Acornfield Road, Knowsley.

The National Planning Policy Framework (NPPF) was published in March 2012, and updated in February 2019 by the Department of Communities and Local Government and replaced all planning policy statements including Planning Policy Statement 25 (PPS 25): Development and Flood Risk. The NPPF set out the Government's planning policies for England and how these are expected to be applied. The Planning Practice Guidance (PPG), provides additional guidance and retains key elements of the now superseded PPS 25.

An initial search on the Environment Agency's (EA) website has identified the development site to be located within Flood Zone 1 and is considered to be very low risk of flooding.

The purpose of this report is to provide details of the site Flood Risk and provide a drainage strategy to cope with surface water runoff generated by the proposed development and mitigate any potential downstream impacts.



Figure 2: Aerial Photo (Google Maps © Bluesky 2021)

2.2 Existing Site

A pre-development topographical survey was carried out by Survey & Engineering Projects ref. S15946-T, dated April 2018. Based on the survey the site slopes towards the south-western corner, with a highpoint to the north-eastern side. Since the existing structure was demolished in 2019, the area mainly consists of the former building slab, associated hardstanding and open field. The site topographical survey is shown in Appendix A. The total site boundary for the site is 13,880m², but all calculations will exclude any TPO tree zones, leaving the boundary at 12,400m².

Existing Site Area	
Hard Landscaping Area	4,800m ²
Soft Landscaping Area	8,944m ²
Total	12,400m ²

Table 1: Existing Areas

2.3 Proposals

The site covers an area of approximately 12,400m² of which 5,340m² is proposed to be roof area, and 6,019m² is external hardstanding. The remaining areas will be soft landscaping. The

proposed development will be made up of an industrial unit as shown on Hale Architect drawing in Appendix B.

Proposed Site Area	
Roof	5,340m ²
Hard Landscaping Area	6,019m ²
Soft Landscaping Area	1,038m ²
Total	12,400m ²

Table 2: Proposed Areas

2.4 Flood Vulnerability Classification

The EA Flood risk map shows the site is located within Flood Zone 1, with a low probability of flooding. This is less than 1 in 1000 (<0.1%) annual probability of flooding from rivers and seas.




Figure 3: EA Flood Map

2.5 Flood Zone Compatibility

In accordance with the NPPF, there are no restrictions upon the type of development within Flood Zone 1. As such the proposed development is compatible within Flood Zone 1. Also, as the site is in Flood Zone 1 the need for an exception test is not required.

3 FLOOD RISK

In accordance with the NPPF and its Technical Guidance document, the risk of flooding from varying sources needs to be considered.

3.1 Rivers

The site is not within any watercourse influence. The closest recorded watercourse based on the EA maps is approximately 700m to the North away from the site and does not impose any flood risk to the proposed development.




Figure 4: Watercourse Location

3.2 Tidal

The site is not within the tidal influence.

3.3 Ground Water

Groundwater flooding is highly variable and dependant on local conditions. A Soil Investigation has been carried out by Delta-Simons dated August 2019 reference 19-0654.02 and based on borehole results, the groundwater is at an average depth of 8.0m below the existing surface. Boreholes logs are shown in Appendix H.

The figure 5 below shows the location of boreholes within the site.




Figure 5: Boreholes' Location

Considering the above, the risk of flooding from groundwater is very low and if any groundwater flooding occurs, it would behave as overland flows and based on the proposed topography of the site it should be directed away from the proposed buildings toward the south boundary.

3.4 Overland Flows

Based on the topographical survey the site levels slope from a high point of 44.00m AOD to the north east and falls to the south west with a low point of 41.50m AOD. The risk of flooding associated within the site areas are shown on the EA surface water flood risk map (Figure 6). The flood depth and velocities in all scenarios, including the high-risk scenario is considered to be very low or negligible as shown in Figures 6, 7 & 8 below.




Figure 6: EA Surface Water Flood Risk Map




Figure 7: EA Surface Water Flood Risk Map - Flood Depth in High Risk Scenario




Figure 8: EA Surface Water Flood Risk Map - Flood Velocity in a High-Risk Scenario

3.5 Sewers

The United Utilities Sewer Records (Appendix C) shows a 300mm diameter public foul water sewer running north through the western side of the site. As the proposals do not see to dramatically increase foul sewage, and the existing foul pipe is shown to be at the start of the foul water run, it is unlikely any risk will be associated with this.

As such, the risk of flooding from sewers is present but very low. The residual risk is due to potential blockages and sewer malfunction.

In the event of a flood, the sewer exceedance flows would behave as overland flows, flowing mainly south-west avoiding the proposed buildings as shown in Appendix D.

3.6 Other Sources

As shown by the EA map below (Figure 9), there is no risk of flooding from reservoirs.

There are no other known sources of flooding within the vicinity of the site and the risk of flooding from other sources is considered very low.




Figure 9: EA Reservoirs Flood Risk Map

3.7 Climate Change

The projected effects of climate change are expected to lead to increased rainfall, increased river flows, raised sea level and tidal fluctuations. The only increases pertinent to this development are from increased rainfall, its effect on drainage systems and potential overland flows.

The EA, as the government's expert on flood risk, has updated these climate change allowances. Following the above, a 40% increase in the peak rainfall intensity (Upper-end category) should be used considering the proposed development lifetime (50 -100 years) and the flood risk due to surface water runoff.

Furthermore, the extreme storm of a 1 in 100-year storm event with a 40% increase in rainfall shall be safely contained on-site, thus preventing any increase in flood risk to adjacent & downstream properties.

As a result of climate change, there would be a slight increase in the risk of flooding by overland flows and sewers; however, the risk would remain low.

3.8 Residual Risk

There are no other known residual risks to the development

4 FLOOD RISK MANAGEMENT

4.1 Floor Levels

To mitigate the flood risk due to surface water, the proposed development levels should be designed to provide flood flow routes within the site away from proposed buildings and access routes in the event of surface water drainage malfunction or during extreme rainfall events falling outside of the design requirements.

4.2 Sustainable Drainage Techniques

The use of various sustainable drainage techniques has been investigated with respect to their potential to be used within the development to control stormwater as close to the source as possible and reduce the potential increased flood risk from the development. They are reviewed in order of Most to Least Sustainable based upon the SuDS Hierarchy table from the EA.

<i>Most Sustainable</i>	SUDS technique	Flood Reduction	Pollution Reduction	Landscape & Wildlife Benefit
	Living roofs	✓	✓	✓
	Basins and ponds - Constructed wetlands - Balancing ponds - Detention basins - Retention ponds	✓	✓	✓
	Filter strips and swales	✓	✓	✓
	Infiltration devices - soakaways - infiltration trenches and basins	✓	✓	✓
	Permeable surfaces and filter drains - gravelled areas - solid paving blocks - porous paviers	✓	✓	
	Tanked systems - over-sized pipes/tanks - storms cells	✓		
<i>Least Sustainable</i>				

Table 3: SuDS Hierarchy

4.2.1 Living Roofs

Living / Green roofs are not recommended for this development due to the severe implications of adopting these systems on an industrial warehouse:

- Structural: Even an extensive green roof system with a 100mm thick growing media will impose considerable loading to a typical lightweight roof system used on these units. Thus, increasing substantially the overall structural requirements.
- Slope: Green roofs are typically installed on flat roofs. The proposed lightweight roof system has a significant slope, and as such specific proprietary systems cannot be implemented.
- Maintenance: Any regular or irregular maintenance to the proposed units high roofs are likely to require the mobilization of elevated platforms and trained personnel.
- Damage & leaks: Although these systems are waterproof, extreme weather factors or human error can result in a leak in the roof. In these restricted conditions, finding and repairing such failure in a complex roof system will be a challenging process.

Although a green roof should always be considered, on this development, the complexity and disadvantages of implementing a green roof are far greater than the potential benefits.

4.2.2 Basins and Ponds

The existing and proposed development layouts have a high percentage coverage of hard landscaping and building plan area, the remaining available land would not be large enough to propose a basin or pond feature.

4.2.3 Filter Strips and Swales

The site layout and the proposed arrangement does not allow for the implementation of swales as these systems require a free large soft landscape area.

4.2.4 Infiltration Devices

Based on the borehole data the underlying sub strata is Clays. Therefore, the use of infiltration techniques is not a feasible option for the site.

4.2.5 Attenuation Tank

The use of an attenuation tank will be required for storage within the site. The storage volume required is 500m³ and will allow the site's discharge rate to drop significantly.

4.2.6 Permeable Paving/Porous Asphalt

The site includes a series of car parking areas that may be suitable for the use of porous asphalt. Storage could be provided within the sub-base material prior to controlled discharge to the public sewer network.

The provision of storage within the sub-base material would only be feasible in areas with a proposed gradient of less than 1 in 20 as detailed within CIRIA RP992/28 (Design Assessment Checklists for Permeable/Porous Pavement). The amount of storage provided within the drainage blanket is subject to sub-base depth.

4.2.7 Rainwater Harvesting Systems

The use of rainwater to provide water for re-use within the proposed unit has been reviewed and ruled out as being not feasible for the following reasons;

- The demand for rainwater re-use on a building of this type is extremely low compared to the potential yield generated. Prolonged storage of rainwater can also lead to water “quality” issues in a holding tank, leading to coloration.
- There is an associated significant increase in CO₂ emissions from the rainwater harvesting systems because of the need to pump stored water from a lower level to different parts of the building at higher levels. This is in conflict with the primary objectives of a sustainable system.

4.2.8 Exceedance Event

Storage will be provided for the 1 in 100 years plus 40% CC event. Storm events in excess of the 1 in 100 years plus 40% CC event should be permitted to produce shallow depth flooding within landscaped areas or adjacent to an attenuation feature. Site levels should be designed to ensure that exceedance flooding is contained on-site to eventually drain back into the drainage system. In the event of rainfall intensities and durations outside of the modelled extreme scenarios or in the case of the drainage system malfunction, the exceedance flows will overflow toward the Southern site boundary as shown on the Exceedance Flow Route Drawing— Appendix D.

4.2.9 Surface Water Treatment

In accordance with the CIRIA C753 publication ‘The SuDS Manual’ (2015), other roofs (non-residential) have a ‘low’ pollution hazard level. Roofs are considered to impose a low risk of pollution to the receiving ground and do not require any sort of specific water treatment other than capturing sediments in the catchpit manholes.

For the yard and carpark areas, treatment of the surface water runoff will be provided by proprietary treatment systems.

The delivery / industrial yard is considered to have a medium pollution hazard level which equates to following pollution hazard indices:

Table 4 below shows the pollution hazard indices for each land use.

Pollution Hazard Indices Land Use	Pollution Hazard Level	Total Suspended Solids (TSS)	Metals	Hydrocarbons
Other Roofs	Low	0.3	0.2	0.05
Industrial/delivery yard	Medium	0.7	0.6	0.7

Table 4: SuDS Pollution Indices

(Table extract is taken from the CIRIA C753 publication 'The SuDS Manual' – Table 26.2

** Indices values range from 0-1.)*

The runoff will be directed to permeable paving where practical (subject to site gradients).

Table 5 below demonstrates that permeable paving provides sufficient treatment to runoff.

Type of SuDS	Total Suspended Solids (TSS)	Metals	Hydrocarbons
Permeable Pavements	0.7	0.6	0.7
Swale	0.5	0.6	0.6
Pond	0.7	0.7	0.5

Table 5: SuDS Mitigation Indices

(Table extract is taken from the CIRIA C753 publication 'The SuDS Manual' – Table 26.3

** Indices values range from 0-1)*

4.3 Surface Water Management

4.3.1 Existing Site Runoff

The existing brownfield runoff rate has been calculated using the modified rational method, as can be seen below in Table 6.

Site Area	Existing Greenfield Run-Off Rates			
	1 in 1 Year Storm Event	1 in 30 Year Storm Event	1 in 100 Year Storm Event	1 in 100+40%CC Year Storm Event
Brownfield (0.48ha)	40.43 l/s	99.17 l/s	128.26 l/s	179.56 l/s

Table 6: Existing Flow Rates

4.3.2 Post-Development Surface Water Run-off

The nature of the proposed development means that there will be an increase in the impermeable areas of the site, resulting in an increase in both volume and the peak rates of run-off of flows when unrestricted. The proposed impermeable area covers approximately 82% of the site. To match a 50% reduction on the existing brownfield 1 in 1 year storm event, a discharge rate of 20 l/s is required.

The on-site surface water drainage network will be split into two separate drainage systems. The surface water from the roof areas and permeable paving will be collected into the tank and then discharge through the hydrobrake. The external yard catchment will flow through a petrol interceptor and then through the hydrobrake. By splitting the systems, this means there will be less overall flow through the petrol interceptor resulting in a more efficient product.

The proposed network relies on the use of drainage channels, pipework, catchpits, attenuation tank, manholes, petrol interceptor and a vortex flow control system to discharge the surface water. Surface water from the attenuation tanks and petrol interceptor will flow into the vortex flow control unit, which will discharge the surface water at a rate of 20 l/s.

Below in Table 7 a comparison can be seen between the existing and proposed situation.

Return Period	Run-off Rate		Betterment
	Existing (unmitigated)	Proposed	
Q ₁	40.43 l/s	20 l/s	50.51%
Q ₃₀	99.17 l/s	20 l/s	79.83%
Q ₁₀₀	128.26 l/s	20 l/s	84.40%
Q _{100+40%}	179.56 l/s	20 l/s	88.86%

Table 7: Existing and Proposed Discharge Rates

The proposed new surface water drainage system has been designed using current MicroDrainage analysis software, ensuring all planning requirements, Lead Local Flood Authorities (LLFA) and EA guidelines are satisfied to prevent uncontrolled flooding of the site and surrounding areas. Microdrainage calculations for the design of the surface water network and attenuation requirements on site are included in Appendix F.

The surface water drainage system proposed for the site is shown in Appendix G. The system shall be designed not to flood for the critical 1 in 100 year design storm plus 40% Climate Change.

4.3.3 Proposed Foul Water Drainage

The proposed foul water will discharge by gravity through private drainage into a private network which will be then linked to public sewer.

A Pre-Planning Enquiry Application to United Utilities would be required to confirm the sewer capacity for the proposed development.

5 OFFSITE IMPACT

The proposed redevelopment of this site results in more impermeable area than in its current use, which will result in an increase of the surface water runoff discharge and volume. To reduce the offsite impact, the surface water drainage network will be designed to cater for up to and including the 1 in 100 year return period storm event, with allowances for climate change (40% increase in rainfall). To minimise the risk to downstream properties the runoff from the 1:100 year storm event with 40% climate change will be kept on the site.

As all the surface water is being controlled and attenuated onsite, the offsite impact is very low.

6 MAINTENANCE STRATEGY

6.1 Manholes, Inspection Chambers, Pipe Work, Drainage Channels & Gullies

The surface water drainage system should be inspected and maintained periodically, primarily to check for silt sedimentation within the system or ingress of any detritus or debris which would decrease system performance. Table 8 sets out the recommended maintenance actions and frequency.

Maintenance schedule	Required action	Typical frequency
Regular Maintenance	Remove manhole and chamber covers to sewers and flow control on network– inspect to ensure water is flowing freely and that the water flow route is unobstructed. Remove debris and silt as required.	Half Yearly Undertake one of these inspections after leaf fall in autumn
Occasional Maintenance	None required	
Remedial Actions	Re-line or replace pipework if unable to clear blockages by jetting.	As required
Monitoring	Inspect chambers for build-up of silt and debris	Half yearly

Table 8: Operation & maintenance requirements for pipe network, manholes & inspection chambers, drainage channels & gullies.

6.2 Vortex Flow Control (Hydrobrake)

The vortex flow control relies typically on its shape to create a vortex within the unit to control the flows to a design point.

These systems have a larger cross-sectional area than that of a comparable orifice that is sized for the same design point, reducing the risk of blockage.

The product specified to be installed is a *Hydrobrake MD-SHE-0190-2000-1600-2000*.

Table 9 sets out the recommended maintenance actions and frequency, refer appendix A for manufacture guidance notes.

Maintenance schedule	Required action	Typical frequency
Regular Maintenance	Inspect and identify if it is not operating correctly. If required, take remedial action.	Initially monthly for 3 months, then half yearly.
Remedial Actions	Repair/rehabilitate flow control.	As required.
Monitoring	Inspect chambers for build-up of silt and debris	Half yearly

Table 9 – Operation & maintenance requirements for vortex flow controls

6.3 Proprietary Surface Water Treatment Systems

These are manufactured products to provide a treatment to the surface water by removing specific pollutants.

Table 10 sets out the recommended maintenance actions and frequency. Manufacturer guidance/recommendations should always be used when available.

Maintenance schedule	Required action	Typical frequency
Regular Maintenance	Remove litter and debris and inspect for sediment, oil and grease accumulation.	Monthly for 3 months, then annually.
	Change the filter media.	As recommended by manufacturer.
	Remove sediment, oil grease and floatables.	As necessary – indicated by system inspections or immediately following significant spill.
Remedial Actions	Replace malfunctioning parts or structures.	As required.
Monitoring	Inspect for evidence of poor operation.	Biannually
	Inspect filter media and establish appropriate replacement frequencies.	Biannually
	Inspect sediment accumulation rates and establish removal frequencies.	Monthly during first half year of operation, then every six months.

Table 10 – Operation & maintenance requirements for proprietary surface water treatment systems - Based on CIRIA SuDS Manual 2015

6.4 Attenuation Tanks

Geocellular attenuation tanks are proposed, they are modular storage systems made with plastic units. These units can be assembled to achieve the required volume and usually on multiple layers. Generally, the units have 95% voids content and are used to create an efficient below ground structure to temporarily store surface water.

Table 11 sets out the recommended maintenance actions and frequency.

Maintenance schedule	Required action	Typical frequency
Regular Maintenance	Inspect and identify any areas that are not operating correctly. If required, take remedial action.	Monthly for 3 months, then annually.
	Remove debris from the catchment surface (where it may cause risks to performance).	Monthly.
	For systems where rainfall infiltrates into the tank from above, check surface of filter for blockages by sediment, algae or other matter; remove and replace surface infiltration medium as required.	Annually.
	Remove sediments from pre-treatment structures and/or internal forebays.	Annually, or as required.
Remedial Actions	Repair/rehabilitate inlets, outlets, overflows and vents.	As required.
Monitoring	Inspect/check all inlets, outlets, vents and overflows to ensure that they are in good condition and operating as designed.	Annually
	Survey inside of tank for sediment build-up and remove if necessary.	Every 5 years or as required.

Table 11 – Operation & maintenance requirements for attenuation storage tanks –
Based on CIRIA SuDS Manual 2015

6.5 Porous Paved Area

The following Table 12 sets out the recommended maintenance actions and frequency for porous paved area. These areas should not be used as storage areas for top soil, sand, etc without the use of a protective layer. The neglect of these areas is likely to reduce the efficiency of the means of drainage.

Maintenance schedule	Required action	Typical frequency
Regular Maintenance	Brushing and vacuuming (standard cosmetic sweep over whole surface)	Once a year, after autumn leaf fall, or reduced frequency as required, based on site-specific observations of clogging or manufacturer's recommendations – pay particular attention to areas where water runs onto pervious surfaces from adjacent impermeable areas as this are is most likely to collect the most sediment.
Occasional Maintenance	Stabilise and mow contributing and adjacent areas.	As required
	Removal of weeds or management using glyphosate applied directly into the weeds by an applicator rather than spraying	As required – once per year on less frequently used pavements.
Remedial Actions	Remediate any landscaping which, through vegetation maintenance or soil slip, has been raised to within 50mm of the level of the surface.	As required
	Remedial works to any depressions, rutting and cracked considered detrimental to the structural performance or a hazard to users, and replace lost jointing material	As required
	Rehabilitation of surface and upper substructure by remedial sweeping.	Every 10 to 15 years or as required (if infiltration performance is reduced due to significant clogging)
Monitoring	Inspect for evidence of poor operation and/or weed growth -if required, take remedial action	Three-monthly, 48 hours after large storms in the first six months
	Inspect silt accumulation rates and establish appropriate brushing frequencies.	Annually
	Monitor inspection chambers	Annually

Table 12 – Operation & maintenance requirements for Porous Paved Area - Based on CIRIA SuDS Manual 2015

7 CONCLUSION

The FRA & Drainage Strategy has considered the potential flood risk to the proposed development and its potential impact on flood risk:

- The development is located in Flood Zone 1.
- The site flood risk is considered low or very low from all sources.
- The development drainage system and levels are designed to accommodate the 100-year rainfall event with a 40% allowance for climate change.
- The proposed development's drainage regime will reduce the onsite and offsite flood risk by having a more resilient surface water drainage system and reducing the peak surface water runoff rates.

Therefore, the FRA & Drainage Strategy concludes that overall this development has a low flood risk both on and offsite.

APPENDICES

Appendix A – Topographical Survey Plan



PLAN GRID NORTH

Figure 1: Schematic representation of the 1200 bp DNA fragment. The fragment is divided into 12 regions labeled a through l. Regions a, b, c, d, e, f, g, h, i, j, k, and l are indicated by arrows pointing to specific sites. Regions a, b, c, d, e, f, g, h, i, j, k, and l are indicated by arrows pointing to specific sites. Regions a, b, c, d, e, f, g, h, i, j, k, and l are indicated by arrows pointing to specific sites.

[illegible]

Client
Hale
198a Providence Square
Jacob Street
London
SE1 2Q7

Project Title
Topographical Survey of Land at:
Acomfield Road
Liverpool
L33

Scale 1:200	Date Apr 18	Drawn D. Wright	Checked R. Cliftchley
		Drawing Ref. S15946-J	Rev A0






Figure 1 is a schematic representation of the experimental design. It shows a sequence of events: a subject is presented with a stimulus (a word), then a response is given (a word), and then a feedback is provided (a word). The sequence is repeated for multiple trials. The feedback is either 'Correct' or 'Incorrect'. The 'Correct' feedback leads to the next trial, while the 'Incorrect' feedback leads to a 'Correct' feedback, which then leads to the next trial. The sequence ends with a 'Correct' feedback.

Source	Year	Estimating	Non-estimating	Imagery
1	1971	346,040 (12)	346,040 (12)	45,135
2	1972	346,040 (12)	346,040 (12)	45,135
3	1973	346,040 (12)	346,040 (12)	45,135
4	1974	346,040 (12)	346,040 (12)	45,135
5	1975	346,040 (12)	346,040 (12)	45,135
6	1976	346,040 (12)	346,040 (12)	45,135
7	1977	346,040 (12)	346,040 (12)	45,135
8	1978	346,040 (12)	346,040 (12)	45,135
9	1979	346,040 (12)	346,040 (12)	45,135
10	1980	346,040 (12)	346,040 (12)	45,135
11	1981	346,040 (12)	346,040 (12)	45,135
12	1982	346,040 (12)	346,040 (12)	45,135
13	1983	346,040 (12)	346,040 (12)	45,135
14	1984	346,040 (12)	346,040 (12)	45,135
15	1985	346,040 (12)	346,040 (12)	45,135
16	1986	346,040 (12)	346,040 (12)	45,135
17	1987	346,040 (12)	346,040 (12)	45,135
18	1988	346,040 (12)	346,040 (12)	45,135
19	1989	346,040 (12)	346,040 (12)	45,135
20	1990	346,040 (12)	346,040 (12)	45,135
21	1991	346,040 (12)	346,040 (12)	45,135
22	1992	346,040 (12)	346,040 (12)	45,135
23	1993	346,040 (12)	346,040 (12)	45,135
24	1994	346,040 (12)	346,040 (12)	45,135
25	1995	346,040 (12)	346,040 (12)	45,135
26	1996	346,040 (12)	346,040 (12)	45,135
27	1997	346,040 (12)	346,040 (12)	45,135
28	1998	346,040 (12)	346,040 (12)	45,135
29	1999	346,040 (12)	346,040 (12)	45,135
30	2000	346,040 (12)	346,040 (12)	45,135
31	2001	346,040 (12)	346,040 (12)	45,135
32	2002	346,040 (12)	346,040 (12)	45,135
33	2003	346,040 (12)	346,040 (12)	45,135
34	2004	346,040 (12)	346,040 (12)	45,135
35	2005	346,040 (12)	346,040 (12)	45,135
36	2006	346,040 (12)	346,040 (12)	45,135
37	2007	346,040 (12)	346,040 (12)	45,135
38	2008	346,040 (12)	346,040 (12)	45,135
39	2009	346,040 (12)	346,040 (12)	45,135
40	2010	346,040 (12)	346,040 (12)	45,135
41	2011	346,040 (12)	346,040 (12)	45,135
42	2012	346,040 (12)	346,040 (12)	45,135
43	2013	346,040 (12)	346,040 (12)	45,135
44	2014	346,040 (12)	346,040 (12)	45,135
45	2015	346,040 (12)	346,040 (12)	45,135
46	2016	346,040 (12)	346,040 (12)	45,135
47	2017	346,040 (12)	346,040 (12)	45,135
48	2018	346,040 (12)	346,040 (12)	45,135
49	2019	346,040 (12)	346,040 (12)	45,135
50	2020	346,040 (12)	346,040 (12)	45,135
51	2021	346,040 (12)	346,040 (12)	45,135
52	2022	346,040 (12)	346,040 (12)	45,135
53	2023	346,040 (12)	346,040 (12)	45,135
54	2024	346,040 (12)	346,040 (12)	45,135
55	2025	346,040 (12)	346,040 (12)	45,135
56	2026	346,040 (12)	346,040 (12)	45,135
57	2027	346,040 (12)	346,040 (12)	45,135
58	2028	346,040 (12)	346,040 (12)	45,135
59	2029	346,040 (12)	346,040 (12)	45,135
60	2030	346,040 (12)	346,040 (12)	45,135
61	2031	346,040 (12)	346,040 (12)	45,135
62	2032	346,040 (12)	346,040 (12)	45,135
63	2033	346,040 (12)	346,040 (12)	45,135
64	2034	346,040 (12)	346,040 (12)	45,135
65	2035	346,040 (12)	346,040 (12)	45,135
66	2036	346,040 (12)	346,040 (12)	45,135
67	2037	346,040 (12)	346,040 (12)	45,135
68	2038	346,040 (12)	346,040 (12)	45,135
69	2039	346,040 (12)	346,040 (12)	45,135
70	2040	346,040 (12)	346,040 (12)	45,135
71	2041	346,040 (12)	346,040 (12)	45,135
72	2042	346,040 (12)	346,040 (12)	45,135
73	2043	346,040 (12)	346,040 (12)	45,135
74	2044	346,040 (12)	346,040 (12)	45,135
75	2045	346,040 (12)	346,040 (12)	45,135
76	2046	346,040 (12)	346,040 (12)	45,135
77	2047	346,040 (12)	346,040 (12)	45,135
78	2048	346,040 (12)	346,040 (12)	45,135
79	2049	346,040 (12)	346,040 (12)	45,135
80	2050	346,040 (12)	346,040 (12)	45,135
81	2051	346,040 (12)	346,040 (12)	45,135
82	2052	346,040 (12)	346,040 (12)	45,135
83	2053	346,040 (12)	346,040 (12)	45,135
84	2054	346,040 (12)	346,040 (12)	45,135
85	2055	346,040 (12)	346,040 (12)	45,135
86	2056	346,040 (12)	346,040 (12)	45,135
87	2057	346,040 (12)	346,040 (12)	45,135
88	2058	346,040 (12)	346,040 (12)	45,135
89	2059	346,040 (12)	346,040 (12)	45,135
90	2060	346,040 (12)	346,040 (12)	45,135
91	2061	346,040 (12)	346,040 (12)	45,135
92	2062	346,040 (12)	346,040 (12)	45,135
93	2063	346,040 (12)	346,040 (12)	45,135
94	2064	346,040 (12)	346,040 (12)	45,135
95	2065	346,040 (12)	346,040 (12)	45,135
96	2066	346,040 (12)	346,040 (12)	45,135
97	2067	346,040 (12)	346,040 (12)	45,135
98	2068	346,040 (12)	346,040 (12)	45,135
99	2069	346,040 (12)	346,040 (12)	45,135
100	2070	346,040 (12)	346,040 (12)	45,135
101	2071	346,040 (12)	346,040 (12)	45,135
102	2072	346,040 (12)	346,040 (12)	45,135
103	2073	346,040 (12)	346,040 (12)	45,135
104	2074	346,040 (12)	346,040 (12)	45,135
105	2075	346,040 (12)	346,040 (12)	45,135
106	2076	346,040 (12)	346,040 (12)	45,135
107	2077	346,040 (12)	346,040 (12)	45,135
108	2078	346,040 (12)	346,040 (12)	45,135
109	2079	346,040 (12)	346,040 (12)	45,135
110	2080	346,040 (12)	346,040 (12)	45,135
111	2081	346,040 (12)	346,040 (12)	45,135
112	2082	346,040 (12)	346,040 (12)	45,135
113	2083	346,040 (12)	346,040 (12)	45,135
114	2084	346,040 (12)	346,040 (12)	45,135
115	2085	346,040 (12)	346,040 (12)	45,135
116	2086	346,040 (12)	346,040 (12)	45,135
117	2087	346,040 (12)	346,040 (12)	45,135
118	2088	346,040 (12)	346,040 (12)	45,135
119	2089	346,040 (12)	346,040 (12)	45,135
120	2090	346,040 (12)	346,040 (12)	45,135
121	2091	346,040 (12)	346,040 (12)	45,135
122	2092	346,040 (12)	346,040 (12)	45,135
123	2093	346,040 (12)	346,040 (12)	45,135
124	2094	346,040 (12)	346,040 (12)	45,135
125	2095	346,040 (12)	346,040 (12)	45,135
126	2096	346,040 (12)	346,040 (12)	45,135
127	2097	346,040 (12)	346,040 (12)	45,135
128	2098	346,040 (12)	346,040 (12)	45,135
129	2099	346,040 (12)	346,040 (12)	45,135
130	2100	346,040 (12)	346,040 (12)	45,135
131	2101	346,040 (12)	346,040 (12)	45,135
132	2102	346,040 (12)	346,040 (12)	45,135
133	2103	346,040 (12)	346,040 (12)	45,135
134	2104	346,040 (12)	346,040 (12)	45,135
135	2105	346,040 (12)	346,040 (12)	45,135
136	2106	346,040 (12)	346,040 (12)	45,135
137	2107	346,040 (12)	346,040 (12)	45,135
138	2108	346,040 (12)	346,040 (12)	45,135
139	2109	346,040 (12)	346,040 (12)	45,135
140	2110	346,040 (12)	346,040 (12)	45,135
141	2111	346,040 (12)	346,040 (12)	45,135
142	2112	346,040 (12)	346,040 (12)	45,135
143	2113	346,040 (12)	346,040 (12)	45,135
144	2114	346,040 (12)	346,040 (12)	45,135
145	2115	346,040 (12)	346,040 (12)	45,135
146	2116	346,040 (12)	346,040 (12)	45,135
147	2117	346,040 (12)	346,040 (12)	45,135
148	2118	346,040 (12)	346,040 (12)	45,135
149	2119	346,040 (12)	346,040 (12)	45,135
150	2120	346,040 (12)	346,040 (12)	45,135
151	2121	346,040 (12)	346,040 (12)	45,135
152	2122	346,040 (12)	346,040 (12)	45,135
153	2123	346,040 (12)	346,040 (12)	45,135
154	2124	346,040 (12)	346,040 (12)	45,135
155	2125	346,040 (12)	346,040 (12)	45,135
156	2126	346,040 (12)	346,040 (12)	45,135
157	2127	346,040 (12)	346,040 (12)	45,135
158	2128	346,040 (12)	346,040 (12)	45,135
159	2129	346,040 (12)	346,040 (12)	45,135
160	2130	346,040 (12)	346,040 (12)	45,135
161	2131	346,040 (12)	346,040 (12)	45,135
162	2132	346,040 (12)	346,040 (12)	45,135
163	2133	346,040 (12)	346,040 (12)	45,135
164	2134	346,040 (12)	346,040 (12)	45,135
165	2135	346,040 (12)	346,040 (12)	45,135
166	2136	346,040 (12)	346,040 (12)	45,135
167	2137	346,040 (12)	346,040 (12)	45,135
168	2138	346,040 (12)	346,040 (12)	45,135
169	2139	346,040 (12)	346,040 (12)	45,135
170	2140	346,040 (12)	346,040 (12)	45,135
171	2141	346,040 (12)	346,040 (12)	45,135
172	2142	346,040 (12)	346,040 (12)	45,135
173	2143	346,040 (12)	346,040 (12)	45,135
174	2144	346,040 (12)	346,040 (12)	45,135
175	2145	346,040 (12)	346,040 (12)	45,135
176	2146	346,040 (12)	346,040 (12)	45,135
177	2147	346,040 (12)	346,040 (12)	45,135
178	2148	346,040 (12)	346,040 (12)	45,135
179	2149	346,040 (12)	346,040 (12)	45,135
180	2150	346,040 (12)	346,040 (12)	45,135
181	2151	346,040 (12)	346,040 (12)	45,135
182	2152	346,040 (12)	346,040 (12)	45,135
183	2153	346,040 (12)	346,040 (12)	45,135
184	2154	346,040 (12)	346,040 (12)	45,135
185	2155	346,040 (12)	346,040 (12)	45,135
186	2156	346,040 (12)	346,040 (12)	45,135
187	2157	346,040 (12)	346,040 (12)	45,135
188	2158	346,040 (12)	346,040 (12)	45,135
189	2159	346,040 (12)	346,040 (12)	45,135
190	2160	346,040 (12)	346,040 (12)	45,135
191	2161	346,040 (12)	346,040 (12)	45,135
192	2162	346,040 (12)	346,040 (12)	45,135
193	2163	346,040 (12)	346,040 (12)	45,135
194	2164	346,040 (12)	346,040 (12)	45,135
195	2165	346,040 (12)	346,040 (12)	45,135
196	2166	346,040 (12)	346,040 (12)	45,135
197	2167	346,040 (12)	346,040 (12)	45,135
198	2168	346,040 (12)	346,040 (12)	45,135
199	2169	346,040 (12)	346,040 (12)	45,135
200	2170	346,040 (12)	346,040 (12)	45,135
201	2171	346,040 (12)	346,040 (12)	



Client
Halle
198a Providence Square
Jacob Street
London
SE1 2DZ

Project Title
Topographical Survey of Land at:
Acomfield Road
Liverpool
L33

Surveyed D. Fleming	Drawn D. Wright	Checked R. Critchley	
Scale 1:200	Date Apr 18	Drawing Ref. S15946-I	Rev No. 05 Size A0 —

