



Knowsley Council

Mrs Olusola Olukoshi
c/o Mr Peter Hamilton - PHPC
40 North Sudley Road
Aigburth
Liverpool
L17 0BG

Our Ref: 22/00644/PDC

Date: 13 December 2022

Dear Sir/Madam

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) ORDER 2015
(AS AMENDED) – SCHEDULE 2, PART 3, CLASS MA

Address of the Proposed Development:

2 St Johns House, Greenfield Walk, Huyton, Knowsley

Description of the Proposed Development:

PRIOR APPROVAL FOR CHANGE OF USE FROM AN OFFICE (USE CLASS E) TO FORM 2
NO. RESIDENTIAL DWELLINGS (USE CLASS C3)

Knowsley Metropolitan Borough Council, as local planning authority, hereby confirm that prior approval is required and granted under Schedule 2, Part 3, Class MA of the Town and Country Planning (General Permitted Development) Order 2015 as amended, subject to the following condition(s):-

1. The development must be begun not later than the expiration of three years beginning with the date of this permission.

Reason: In order to comply with the requirements of Section 91 of the Town and Country Planning Act 1990 (as amended) and with paragraph MA.2 (5) of Part 3, Class MA of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

2. The development hereby permitted shall be carried out in accordance with the approved plans and documents listed in Schedule 1.

Reason: For the avoidance of doubt.

3. Any building permitted to be used as a dwellinghouse by virtue of Class MA is to remain in use as a dwellinghouse within the meaning of Class C3 of Schedule 1 to the Use Classes Order and for no other purpose, except to the extent that the other purpose is ancillary to the use as a dwellinghouse.

Reason: In accordance with Paragraph MA.2 (6) of Part 3, Class MA of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).



Knowsley Metropolitan Borough Council
PO Box 21 Archway Road Huyton Knowsley Merseyside L36 9YU
www.knowsley.gov.uk



4. No part of the development shall be brought into use until visibility splays of 2 metres by 2 metres have been provided on each side of the access. The depth shall be measured from the back of footway/verge into the site and the width measured outward from the edges of the access. The splays shall be provided clear of obstructions to visibility above the height of 0.6 metres measured from the footway/verge level. Once created, the visibility splays shall be maintained clear of any obstruction and shall be retained at all times.

Reason: To provide the driver of a vehicle using the access and other users of the public highway with adequate inter-visibility and to comply with the National Planning Policy Framework, Policies CS2, CS7 and CS19 of the Knowsley Local Plan: Core Strategy, adopted January 2016.

Important Information

The development must be carried out in accordance with the details provided in the application unless the local planning authority and the developer agree otherwise in writing.

Information that the Developer Provided to the Local Planning Authority:

Date Received	Ref. No	Version	Drawing/Document Title
17/10/2022	-	-	SUPPORTING STATEMENT OCTOBER 2022
17/10/2022	139_SP_001	-	LOCATION PLAN AND BLOCK PLAN
17/10/2022	139_SP_005	REV A	SITE PLAN AND GROUND FLOOR PLAN (EXISTING)
17/10/2022	139_SP_006	-	SITE PLAN AND ROOF PLAN (EXISTING)
17/10/2022	139_SP_007	-	EXISTING FRONT AND REAR ELEVATIONS
17/10/2022	139_SP_008	-	EXISTING SIDE ELEVATIONS
17/10/2022	139_SP_010	REV D	PROPOSED FLOOR PLAN AND SITE PLAN
17/10/2022	139_SP_011	REV B	PROPOSED ROOF PLAN
17/10/2022	139_SP_012	REV A	PROPOSED FRONT AND REAR ELEVATIONS
17/10/2022	139_SP_013	-	PROPOSED SIDE ELEVATIONS

NOTE FOR APPLICANT: The applicant's attention is drawn to the following comments;

1. *Application for Planning Permission*

This decision does not confer approval under the prior approval process for any associated external works or building operations associated with the change of use shown on the submitted plans. A separate application for planning permission for any external development associated with the change of use will be required,

2. *Coal Mining Standing Advice*

The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848.

Further information is also available on the Coal Authority website at:

www.gov.uk/government/organisations/the-coal-authority

3. *Merseyside Fire and Rescue Authority*

The comments of Merseyside Fire and Rescue Authority in their letter dated 26 October 2022 (as attached).

4. *Contaminated Land - Advisory Note*

Based on the information available to this division we are not aware of any contamination on this site. However, the responsibility to properly address contaminated land issues lies with the owner/developer of the site, irrespective of any involvement by this Authority. The applicant/developer is requested to contact the Council's Environmental Protection Unit (Tel: 0151 443 4712) as soon as is practicable should contamination be encountered during the development of the site.

If contaminated material is encountered the applicant/developer is required to dispose of the contaminated arisings appropriately. They should also be aware of their health and safety responsibilities to workers in respect of handling such materials. The developer should also ensure that no pathways are created by which any contamination may either migrate off-site or affect site users.

5. *Street Naming and Numbering*

The developer will be required to contact:

street.naming.numbering@knowsley.gov.uk to arrange for addresses to be allocated to the development.

Please note there is a fee for this process and details can be found on the Council's website by following the link below:

<https://www.knowsley.gov.uk/residents/building-and-planning/register-street-name-or-house-number/street-naming-and-numbering-charges>

If you require any further information please contact Maxine Wishart on 0151 443 2319.

Yours faithfully

Dale Milburn

Executive Director - Regeneration and Economic Development

Knowsley MBC
Planning Department
Municipal Buildings
Archway Road
Huyton
L36 9YU

Email:
dcconsultations@knowsley.gov.uk

**Merseyside Fire & Rescue Authority
Community Fire Protection**

Fire Engineering Team
Service Headquarters
Bridle Road
Bootle
Merseyside
L30 4YD

Telephone: 0151 296 6590 (Calls may be recorded)
Inspecting Officer: Alison Harrison
Email: fireengineeringteam@merseyfire.gov.uk
web Site: www.merseyfire.gov.uk

Your ref: 22/00644/PDC

Our ref:00444133/950771/AH/BOC

Date: 26th October 2022

Dear Sir/Madam,

THE TOWN AND COUNTRY PLANNING ACT 1990
PLANNING APPLICATION NUMBER REF: 22/00644/PDC
PROPOSAL: PRIOR APPROVAL FOR CHANGE OF USE FROM AN OFFICE (USE
CLASS E) TO FORM 2 NO. RESIDENTIAL FLATS (USE CLASS C3)
ADDRESS: ST JOHNS HOUSE 2 GREENFIELD WALK HUYTON KNOWSLEY L36 0XP

The Fire Authority requests that any decision notice includes the following information;

The plans relating to the above application have been examined and below are the Fire Authority's observations:

- * Access for fire appliances should comply with the requirements of Section B5, Schedule 1 of the Building Regulations. Provisions for access will depend on the size and use of the building. The design of the access route, for example minimum road widths and maximum reversing distances, should also be considered (Appendix A, attached).
- * In accordance with Section 55 of the County of Merseyside Act 1980, the position of the premises should not compromise or impede existing means of fire service access to a neighbouring building.
- * Water supplies for firefighting purposes (Appendix B) should be risk assessed in accordance with the undermentioned guidance in liaison with the water undertakers (United Utilities - 0161 907 7351) with suitable and sufficient fire hydrants supplied.

Housing

Housing developments with units of detached or semidetached houses of not more than two floors should have a water supply capable of delivering a minimum of eight litres per second through any single hydrant. Multi occupied housing developments with units of more than two floors should have a water supply capable of delivering a minimum of 20 to 35 litres per second through any single hydrant on the development.

Further information regarding access requirements can be found in the current version of Approved Document B, which is available for free download via:

<https://www.gov.uk/government/publications/fire-safety-approved-document-b>

Should you require any further information in respect of this correspondence please contact the Officer named above

Yours faithfully



Alison Harrison
Authorised Fire Safety Inspecting Officer
And on behalf of Merseyside Fire and Rescue Authority



Appendix A - Access and Facilities for the Fire Service as given in Section B5 of Approved Document B

Domestic Dwellings

For dwelling houses, access for a pumping appliance should be provided to within 45m of all points inside the dwelling house.

For flats, either: access for a pumping appliance should be provided to within 45m of all points inside each flat of a block, measured along the route of the hose; or fire mains should be provided.

Commercial Buildings

Small buildings (up to 2000m², with a top occupied storey a maximum of 11m above ground level), require access for a pump appliance to 15% of the perimeter, or within 45m of every point of the footprint of the building, whichever is the less onerous.

Larger buildings will require access to a percentage of the perimeter that increases incrementally with size of the total floor area and height of building – please see details in Approved Document B Volume 2 Section 15.

Elevations to which vehicle access is provided will require a door, to give access into the building. The maximum distance between doors, or between a door and the end of the elevation, is 60m (ie a 150m elevation would need a minimum of two doors).

All Buildings

Access routes and hardstanding should comply with Table 13.1 ADB Volume 1 / Table 15.2 ADB Volume 2. Please note: MFRS appliances are 17 tonnes (pump) and 26 tonnes (high reach).

Dead-end access routes longer than 20m require turning facilities (eg a turning circle or hammer head, or other turning point).

Where fire mains are fitted, access should be provided for a pumping appliance to within 18m of each fire main inlet connection point. Inlets should be on the face of the building and visible from the parking position of the appliance. The run of horizontal internal connecting pipe should be a maximum of 18m in length.

Buildings with a storey more than 18m above the fire service vehicle access level, or a basement more than 10m below, should have one or more firefighting shafts containing fire-fighting lifts and fire mains (a minimum of two fire-fighting shafts will be required for buildings with a floor area of 900 m² or more).

Buildings in the 'shop and commercial', 'assembly and recreation' or 'industrial' purpose groups (Groups 4, 5, or 6), with a storey area of 900m² or more and a storey height of 7.5m or more above fire service vehicle access level will require at least two firefighting shafts (firefighting lifts may not be needed).



Entry to a firefighting shaft at fire service access level should be available either directly from the open air or by way of a protected corridor not exceeding 18m in length. The corridor is deemed to be part of the firefighting shaft, and any access to it from the accommodation should be by way of protected lobbies.

Hydrants

Where a building has a compartment with an area of more than 280m² and is being erected more than 100m from an existing fire hydrant, additional hydrants are required as follows:

Buildings with fire main – hydrant within 90m of dry fire main inlet;

Buildings without fire main – hydrant within 90m of an entrance to the building; and a maximum of 90m apart.

Appendix B - Guidelines on flow requirements for firefighting

The following flows represent the ideal requirements on new developments and during permanent system changes.

Housing

Housing developments with units of detached or semidetached houses of not more than two floors should have a water supply capable of delivering a minimum of eight litres per second through any single hydrant. Multi occupied housing developments with units of more than two floors should have a water supply capable of delivering a minimum of 20 to 35 litres per second through any single hydrant on the development.

Transportation

Lorry/coach parks - multi-storey car parks - service stations.

All of these amenities should have a water supply capable of delivering a minimum of 25 litres per second through any single hydrant on the development or within a vehicular distance of 90 metres from the complex.

Industry

The water supply infrastructure to any industrial estate should be as follows with the mains network on site being normally at least 150 mm nominal diameter—

Up to one hectare 20 litres per second.

One to two hectares 35 litres per second.

Two to three hectares 50 litres per second.

Over three hectares 75 litres per second.



Shopping, offices, recreation and tourism

Commercial developments of this type should have a water supply capable of delivering a minimum flow of 20 to 75 litres per second to the development site.

Education, health and community facilities

Village halls— Should have a water supply capable of delivering a minimum flow of 15 litres per second through any single hydrant on the development or within a vehicular distance of 100 metres from the complex.

Primary schools and single storey health centre's— Should have a water supply capable of delivering a minimum flow of 20 litres per second through any single hydrant on the development or within a vehicular distance of 70 metres from the complex.

Secondary schools, colleges, large health and community facilities— Should have a water supply capable of delivering a minimum flow of 35 litres per second through any single hydrant on the development or within a vehicular distance of 70 metres from the complex.

