

ABOVE GROUND DRAINAGE
 All internal drainage fittings to discharge into 100mm SVPs as indicated on the drawing.
 All SVPs to have a minimum 100mm uPVC trap seals or as specified by manufacturers and in accordance with AD84 of National Building Regs. Waste pipes to connect in SVPs
 200mm above lowest waste connection.
 Waste pipes to be uPVC to the following sizes:
 WNB: 32mm diameter;
 Showers, baths and sinks: 40mm dia with 75mm deep seal trap;
 WC: 110mm dia hespele pipe via Hunter S200 or similar approved manifold;
 Cisterns: 100mm over 100mm;
 Washing machines and Dishwashers: 40mm with 75mm deep seal trap.
 SVP to be located internally and to terminate at plastic cage minimum 900mm above top of any opening lights with new 110mm uPVC connection to existing drainage.
 Branch connections exceeding 1700mm to be fitted with Hunter or similar approved anti-siphon air admittance valves.