


Carbon filter odour control

There are many carbon filter systems for commercial kitchen which chosen (KITCHAVENT 2000) to be fit and manufacturer specification documents provided and as grease filter(baffle filter) already installed in canopy this unit will provide good odour and smoke control.

External ventilation and Stack

The stack will be above the ridge of building by 1 meter to comply with Defra Documents and will fit turbo cowl as stack and the noise level will be less than by 5dB of the normal noise at 1 meter of nearest window where the system fitted complying with BS 4142:2014+A1:2019.



Pizza oven canopy

We will fit canopy above the pizza oven as decide to fit gas or electric pizza oven to ensure to remove any smell and smoke and will connected to duct pipe which connected to main canopy which connected through duck to the stack till 1 meter above the ridge of building as this comply to Defra Documents.